

Room Name	Reporting Room	Room Number REPR
Revision	1	
Issue Date	29.05.2019	
BRIEFING		
Briefed Area	12.00 m ²	
Hours of Operation	Available 24 Hours	
Occupancy	Up to 4 (6 to 8 for limited periods for image reviews by team)	
Acoustics	Sound attenuation level high, acoustic privacy is required.	
Remarks		
Description / Special Requirements	Room within a Clinical or Diagnostic Unit for reviewing and reporting of computerised patient imaging/PACS images. Film images may also be viewed from time to time.	
SERVICES		
General Requirements	BODY PROTECTED <input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING <input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure <input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust <input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected <input type="checkbox"/>	LIGHTING: dimmable <input checked="" type="checkbox"/>
	LIGHTING: downlights <input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights <input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general <input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM <input type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	both sides
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLCP-006	FLOOR FINISH: carpet, carpet tiles, 90/10 wool/nylon	
FLSK-009	SKIRTING: vinyl, feather edged, 150H, prefinished	or floor vinyl covered skirting
WLWA-001	WALL FINISH: acoustic panels, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQCW-016	BIN: waste, general, 20L	3	2	
FIHR-075	BRACKET: for computer CPU, underdesk mounted	2	2	
FIHR-070	BRACKET: for display screen, dual, desk mounted	3	4	

Room Name | Reporting Room
Room Number REPR

AusHFG code	Description	Group	Qty	Comment
FIHR-066	BRACKET: for display screen, wall mounted, articulated, adj height	2	2	optional, for wall mounted display screen, 1 per workstation
FIJO-212	BULKHEAD: joinery	1	1	
FIJO-099	CAC: cable access cap	3	2	
FQBS-018	CHAIR: office, ergonomic	3	3	1 per workstation
ITNE-068	COMPUTER: hi performance, for clinical / PACS use, CPU, underbench mount	3	2	
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	1	
ITNE-063	DISPLAY SCREEN: for computer	3	4	RIS/PMS monitor per workstation
ITNE-070	DISPLAY SCREEN: PACS	3	2	optional, wall mounted for viewing by teams, 1 per workstation
ITNE-069	DISPLAY SCREEN: PACS, portrait	3	4	
FIHR-026	HOOK: coat	1	2	optional
ITNE-067	KEYBOARD: keyboard and mouse only	3	2	
FQDW-043	PARTITION: workstation system, acoustic	3	1	
ITNE-049	TELEPHONE: handset, desktop	3	2	
MMGE-152	VIEWER: X-ray, 2 screen	1	2	1 per workstation
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	optional
FQDW-044	WORKSTATION: straight, adj height, 1800W x 800D x 750H nom.	3	2	adjustable sit to standing height workstation optional

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITIN-145	DESK BOX: for power, data, AV, flush mounted, softwired	1	2	
ELGP-212	GPO: double, desk box	1	8	
ELGP-208	GPO: double, wall mounted	1	2	to bench, x-ray viewer
ELGP-109	GPO: single, wall mounted	1	2	optional, for use with wall mounted display screen, 1 per workstation
ELGP-109	GPO: single, wall mounted	1	2	1 to each workstation for deskbox soft wired deskbox connection
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
LIFX-011	LIGHT: reading light	1	2	1 per w/s - task light
ITIN-029	OUTLET: data, double RJ45, desk box	1	4	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	4	2 to each workstation for deskbox soft wired deskbox connection
ITIN-067	OUTLET: HDMI, desk box	1	2	optional, 1 per workstation
ITIN-066	OUTLET: HDMI, wall mounted	1	2	optional, for use with wall mounted display screen, 1 per workstation

Room Name | Reporting Room

Room Number REPR

AusHFG code	Description	Group	Qty	Comment
ITIN-066	OUTLET: HDMI, wall mounted	1	2	1 to each workstation for deskbox soft wired deskbox connection
ELBO-012	SWITCH: light, dimmer	1	3	to room