

Room Name	Reporting Workstation	Room Number	REPW
Revision	1		
Issue Date	29.05.2019		
BRIEFING			
Briefed Area	6.00 m ²		
Hours of Operation	Available 24 Hours		
Occupancy	1 staff member, 1 supervisor on occasion		
Acoustics	Acoustic privacy is required		
Remarks			
Description / Special Requirements	Single workstation within a Clinical or Diagnostic unit for reviewing and reporting of computerised patient imaging/ PACS images. Intended for use as a component in spaces with more than one workstation.		
SERVICES			
General Requirements	BODY PROTECTED	<input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable <input checked="" type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLCP-006	FLOOR FINISH: carpet, carpet tiles, 90/10 wool/nylon	
FLSK-009	SKIRTING: vinyl, feather edged, 150H, prefinished	or floor vinyl covered skirting
WLWA-001	WALL FINISH: acoustic panels, prefinished	to long edge of w/s where it abuts a wall
WLWA-004	WALL FINISH: paint, acrylic, washable	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQCW-016	BIN: waste, general, 20L	3	1	
FIHR-075	BRACKET: for computer CPU, underdesk mounted	2	1	
FIHR-004	BRACKET: for display screen, ceiling mounted	1	1	optional, for ceiling mounted display screen
FIHR-070	BRACKET: for display screen, dual, desk mounted	3	2	
FIJO-099	CAC: cable access cap	3	1	
FQBS-018	CHAIR: office, ergonomic	3	2	optional, 1 per w/s with a 2nd per w/s

Room Name | Reporting Workstation
Room Number REPW

AusHFG code	Description	Group	Qty	Comment
ITNE-068	COMPUTER: hi performance, for clinical / PACS use, CPU, underbench mount	3	1	
ITNE-063	DISPLAY SCREEN: for computer	3	2	RIS/PMS monitor per w/s
ITNE-070	DISPLAY SCREEN: PACS	3	1	optional, ceiling mounted, for viewing by teams
ITNE-069	DISPLAY SCREEN: PACS, portrait	3	2	
ITNE-067	KEYBOARD: keyboard and mouse only	3	1	
FQDW-043	PARTITION: workstation system, acoustic	3	2	
ITNE-049	TELEPHONE: handset, desktop	3	1	
FQDW-044	WORKSTATION: straight, adj height, 1800W x 800D x 750H nom.	3	1	adjustable sit to standing height workstation optional

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITIN-145	DESK BOX: for power, data, AV, flush mounted, softwired	1	1	
ELGP-212	GPO: double, desk box	1	4	
ELGP-101	GPO: single, ceiling mounted	1	1	optional, for use with optional large format ceiling mounted display screen, 1 per w/s
ELGP-109	GPO: single, wall mounted	1	1	for deskbox soft wired deskbox connection
LIFX-011	LIGHT: reading light	1	1	
ITIN-029	OUTLET: data, double RJ45, desk box	1	2	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	for deskbox soft wired deskbox connection
ITIN-061	OUTLET: HDMI, ceiling mounted	1	1	optional, for use with optional large format ceiling mounted display screen, 1 per w/s
ITIN-067	OUTLET: HDMI, desk box	1	1	optional
ITIN-066	OUTLET: HDMI, wall mounted	1	1	optional, for deskbox soft wired deskbox connection
ELBO-012	SWITCH: light, dimmer	1	1	