

Room Name	Scrub Up, 4m2		Room Number
			SCRB-4
Revision	1		
Issue Date	02.07.2018		
BRIEFING			
Briefed Area	4.00 m ²		
Hours of Operation	24 Hours		
Occupancy	Up to 3 staff		
Acoustics			
Remarks			
Description / Special Requirements	The Scrub-up room provides an area for pre-operative scrubbing and gloving. Additional Design Considerations: A minimum of 900mm is required between scrub stations. Taps to be non touch - automatically operated. For those health services using rub-scrub, use optionally in lieu of alcohol based hand rub dispensers.		
SERVICES			
General Requirements	BODY PROTECTED	<input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input checked="" type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	to wet zone
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-019	WALL FINISH: vinyl, full height	
WLPR-006	WALL PROTECTION: corner guards	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQCW-016	BIN: waste, general, 20L	3	1	
ITCL-018	CLOCK: clock system slave, digital	1	1	mount flush with wall
FIDI-001	DISPENSER: alcohol based hand rub	2	2	
FIDI-014	DISPENSER: disposable glove	2	1	for non-sterile gloves
FIDI-025	DISPENSER: paper/hand towel	2	1	
FIDI-028	DISPENSER: scrub brush	2	1	
FIDI-031	DISPENSER: soap antiseptic	2	2	

Room Name | **Scrub Up, 4m2**
Room Number **SCRB-4**

AusHFG code	Description	Group	Qty	Comment
FIBM-006	MIRROR: fixed, glass	1	1	
FQSM-041	SHELVING: stainless steel wire mesh, 600W x 400D x 2100H, mobile	3	1	for sterile gloves, masks etc
HYBA-077	SINK: trough, scrub	1	1	
HYTP-042	TAPWARE: sensor	1	2	sensor to be integral to tapware, not placed to side or above

Engineering Services