Australasian Health Facility Guidelines

Room Data Sheet

Room Name	Scrub Up / Gowning, 6m2	Room Number SCRB-6				
Revision	3					
Issue Date	20.03.17					
BRIEFING						
Briefed Area	6.00 m ²					
	6.00 m 24 Hours					
Hours of Operation Occupancy	Up to 2					
Acoustics	00102					
Remarks						
Description / Special Requirements	The Scrub-up/ Gowning 6m2 provides for pre-operative scrubbing and gowning/ gloving, located adjacent to a Procedures Room or Imaging Room. Additional Design Considerations: A minimum of 800mm is required between scrub stations. Taps to be non touch - automatically operated or foot operated.					
SERVICES General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No				
Air	AIRCONDITIONING = Yes	AIRCONDITIONING: hepa filtered = No				
	AIRCONDITIONING: positive pressure = No	AIRCONDITIONING: negative pressure = No				
	EXHAUST: room exhaust = No	VENTILATION = No				
Lighting LIGHTING: colour corrected = No		LIGHTING: dimmable = No				
	LIGHTING: downlights = No	LIGHTING: downlights, dimmable = No				
	LIGHTING: fluorescent, downlights = No	LIGHTING: fluorescent, flush with ceiling, tamper proof = No				
	LIGHTING: fluorescent, general = Yes	LIGHTING: indirect = No				
Nurse Call	NURS CAL SYSTEM = 10					

Room Fabrics

AusHFG code Description		Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	to wet zone
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-005	WALL FINISH: paint, scrub resistant	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	Equal to 'Acrovyn'

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
ITCL-014	CLOCK: analogue, electric	1	1	
FIDI-028	DISPENSER: scrub brush	3	2	
FIDI-031	DISPENSER: soap antiseptic	2	2	
MMGE-048	LINEN CARRIER: dirty, single	3	1	
FIJO-200	SHELF: stainless steel, over scrub sink, wall mount	1	1	over scrub trough
HYBA-077	SINK: trough, scrub	1	1	auto/knee operated taps x 2





Room Name Scrub Up / Gowning, 6m2

Room Number SCRB-6

AusHFG code	Description	Group	Qty	Comment
HYTP-042	TAPWARE: sensor	1	2	
MMGE-122	TROLLEY: gowns	3	1	

Engineering Services

RETIRED

