

Room Name	Scrub Up / Gowning - Shared, 10m2		Room Number SCRBS
Revision	4		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	10.00 m ²		
Hours of Operation	24 Hours		
Occupancy	Up to 2		
Acoustics	Sound attenuation level medium, Acoustic privacy is required.		
Remarks			
Description / Special Requirements	The Shared Scrub-up Gowning room provides an enclosed area for pre-operative scrubbing and gowning/ gloving, shared between two Operating/ Procedure Rooms. Additional Design Considerations: A minimum of 800mm is required between scrub stations. Taps to be non touch - automatically operated or foot operated.		
SERVICES			
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = No		

RETIRED

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	910mm clear opening to Operating Rooms, double swing
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	Equal to 'Acrovyn'
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Equal to 'Acrovyn'
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	to wet zone
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
DWOB-003	OBSERVATION: internal window, alum/glass, double glazed, integral venetian blind, powdercoat	to Operating Rooms, optional
DWOB-010	OBSERVATION: through door/s, glass, clear	with cover, (sliding)
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-005	WALL FINISH: paint, scrub resistant	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	As required, Equal to 'Acrovyn'

Fittings, Furniture and Equipment (FF&E) Items

Room Name | Scrub Up / Gowning - Shared, 10m2

Room Number SCRBS

AusHFG code	Description	Group	Qty	Comment
DWWD-007	BLIND: venetian, integral	1	2	to internal windows if provided
ITCL-014	CLOCK: analogue, electric	1	1	
FIDI-028	DISPENSER: scrub brush	3	4	
FIDI-031	DISPENSER: soap antiseptic	2	4	
MMGE-048	LINEN CARRIER: dirty, single	3	2	
FIJO-194	SHELF: laminate	1	2	over linen carriers
FIJO-200	SHELF: stainless steel, over scrub sink, wall mount	1	1	over scrub trough
HYBA-077	SINK: trough, scrub	1	2	auto/knee operated taps x 2 each trough
HYTP-042	TAPWARE: sensor	1	4	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-109	GPO: single, wall mounted	1	1	for clock
ELBO-015	SWITCH: light, single	1	1	

RETIRED