

Room Name	Screening Room (Fluoroscopy)	Room Number SCR N
<b>Revision</b>	3	
<b>Issue Date</b>	20.03.17	
<b>BRIEFING</b>		
<b>Briefed Area</b>	36.00 m <sup>2</sup>	
<b>Hours of Operation</b>	Available 24 Hours	
<b>Occupancy</b>	1 patient; 1 - 2 staff	
<b>Acoustics</b>		
<b>Remarks</b>		
<b>Description / Special Requirements</b>	Screening Room (Fluoroscopy) is a room for undertaking radiographic procedures involving contrast media. Patient Change, Toilets and Shower should be located in close proximity. The room may include a preparation area with sink. Additional Design Requirements: Radiation shielding to walls and glazing as advised by Radiation Consultant. Unistrut type ceiling may be required, depending on equipment to be installed. Cable ducting between the X-ray table, vertical bucky and control area may be required, depending on equipment type and layout. 'X-ray in Use' warning lights will be required outside each entry door. Dimmable downlights are optional.	
<b>SERVICES</b>		
<b>General Requirements</b>	BODY PROTECTED = Yes	CARDIAC PROTECTED = Yes
<b>Air</b>	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
<b>Lighting</b>	LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = Yes LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
<b>Nurse Call</b>	NURSE CALL SYSTEM = Yes	

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-008	CEILING: plasterboard, drop-in tiles, prefinished, 600 x 1200	at 3000 mm AFFL
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-026	DOOR: 1600mm c/o, 1 1/2 leaf, solid core, lead shielding, paint	Patient entry/exit, min. 1400mm clear opening
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	to Patient Change/ Toilet, number to suit layout
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	equal to Acrovyn
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
DWOB-009	OBSERVATION: internal window, lead glass, clear	to control booth
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin & sink, tiles also acceptable

**Fittings, Furniture and Equipment (FF&E) Items**

**Room Name | Screening Room (Fluoroscopy)**
**Room Number SCR N**

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	
HYBA-010	BASIN: handwash, Type B	1	1	refer BHWS-B (similar)
FIJO-020	BENCH: 600D, open under, laminate finish	1	1	workstation
FIJO-060	BENCH TOP: 600D, joinery under, stainless steel lipped	1	1	wet edge
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FIHR-013	BRACKET: for monitor, ECG	3	1	
MMMI-283	BUCKY: wall, general X-Ray	1	1	
FQBS-014	CHAIR: client	3	1	
ITNE-009	COMPUTER: hi performance, for clinical / PACS use	3	1	flat screen
MMMI-117	CONSOLE: control, fluoroscopy/screening	1	1	
FIJO-136	CUPBOARD: underbench, double door, adj shelves, lockable	1	2	
FIJO-145	CUPBOARD: wall mount, double door, adj shelves, lockable	1	2	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	to services panel
MGFP-004	FLOWMETER: oxygen	3	1	to services panel
MMMI-120	GENERATOR: radiology, fluoroscopy/screening	1	1	
FQDW-005	KEYBOARD SHELF: slide out, for workstation	1	1	for PACS computer screen
FIHR-044	RACK: lead apron	1	1	
MMMI-350	SCREEN: radiation, lead glass	1	1	control booth
HYBA-051	SINK: single	1	1	warm water
MMMI-124	STAND: floor, with patient table, fluoroscopy/screening	1	1	
MMGE-100	SUCTION BOTTLE	3	1	
MMMI-125	SYSTEM: imaging, fluoroscopy/screening imaging unit	1	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
HYTP-038	TAPWARE: mixer, elbow levers, long	1	1	to sink
ITNE-050	TELEPHONE: handset, desktop, handsfree	3	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	on services panel
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel
ELGP-206	GPO: double, on services panel, RCD protected	1	1	on services panel
ELGP-208	GPO: double, wall mounted	1	4	
ELGP-122	GPO: emergency power, single, on services panel	1	2	on services panel
ELGP-105	GPO: single, on services panel	1	2	on services panel

**Room Name | Screening Room (Fluoroscopy)**
**Room Number SCRN**

AusHFG code	Description	Group	Qty	Comment
ELGP-106	GPO: single, special, for equipment	1	2	Xray Fluoroscopy Equipment, chest bucky
ITSE-029	INTERCOM: audio, wall mount	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	3	1 outlet for telephone
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	on services panel
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	on services panel
MGAS-062	OUTLET: suction, on services panel	1	1	on services panel
MMSP-026	SERVICES PANEL: wall mounted	2	1	flush mounted
WLSH-004	SHIELDING: lead lining	1	1	to walls and doors as specified
ELBO-015	SWITCH: light, single	1	5	