

Room Name	Seclusion Room	Room Number SECL
Revision	5	
Issue Date	02.07.2018	
BRIEFING		
Briefed Area	14.00 m ²	
Hours of Operation	24 Hours	
Occupancy	1 patient; 1-2 staff intermittently	
Acoustics	Sound attenuation level very high, acoustic privacy is required.	
Remarks		
Description / Special Requirements	<p>A Seclusion Room provides for the sole confinement of a distressed or agitated person requiring separation for short periods at any hour of the day or night on an involuntary basis. An external outlook is required. All glazing (including external windows) is to be Grade A safety glass to comply with AS/NZS 2208 and AS 1288, specifically, toughened laminated glass with a minimum thickness of 14.28mm, or equivalent approved. Jurisdictional requirements may require an increase in the thickness of the glass for Seclusion Rooms. Door and joinery hardware and any engineering services outlets must not provide ligature points and must be tamper proof. General lighting must be dimmable and/or have controlled switching to create a low stimulus environment. An internal observation window is required so observation is optimised and blind spots eliminated. Designers must carefully consider the design of the door, to ensure it has sufficient strength and robustness but still allows for speech to be heard through it. All finishes to be flush and not provide ligature points. Consider location of wi-fi access points to ensure strong wi-fi coverage is provided for mobile duress functions. Jurisdictional policy to be read in conjunction with guidelines.</p>	
SERVICES		
General Requirements	BODY PROTECTED <input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING <input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure <input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust <input checked="" type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected <input checked="" type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights <input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights <input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input checked="" type="checkbox"/>
	LIGHTING: fluorescent/LED, general <input type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM <input type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLFS-005	CEILING: plasterboard, flush set, suspended, paint, scrub resistant	Min. 3000mm height, impact resistant & sealed, robust and not able to be penetrated, consider plywood or equivalent backing to ceiling finish for high dependency and intensive care areas.
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGL-075	DOOR: 1270mm c/o, single leaf, observation panel, solid core/safety glass, paint	50mm solid core door; outward opening, 180 deg swing. Anti ligature hardware; locks to be provided at top bottom and centre of door; key cylinder to centre lock to both sides of door and flush to inside face of door; snibs to top and bottom locks to outside face of door only. Speech to be audible through door, alternatively intercom to be provided. Security-grade noggings will be required to

Room Name | Seclusion Room
Room Number SECL

AusHFG code	Description	Comment
		support weight of door and resist attempts to force the door.
FLVY-002	FLOOR FINISH: vinyl, seamless, coved, cushioned	Secure fixings with acoustic underlay.
DWOB-006	OBSERVATION: internal window, alum/safety glass, double glazed, integral venetian blind, powdercoat	Grade A safety glass, controls outside room.
FLSK-011	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished, anti ligature	Seamless painted bullnose timber capping to match wall function, to terminate/ secure coved vinyl skirting at approx. 40mm off the finished floor level for cleaning purposes, fully glued and screw fixed at 100mm intervals.
WLWA-005	WALL FINISH: paint, scrub resistant	Walls to be robust and not able to be penetrated.
DWWH-005	WINDOW	External windows double glazed Grade A safety glass with integral venetians.

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
DWWD-007	BLIND: venetian, integral	1	3	To window, observation panel, controls outside room.
FQBS-047	MATTRESS: foam	3	1	On floor.
FIBM-004	MIRROR: fixed, convex, tamper proof, anti ligature	1	1	Securely fixed within a frame and infilled.

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	Optional; outside room. Mobile duress preferred.
DWWD-010	CONTROL: venetian blind, remote	1	2	Outside room, for remote control of blinds to external windows.
FSDE-004	DETECTOR: smoke	1	1	
ELGP-208	GPO: double, wall mounted	1	1	Outside room, close to entrance door for mechanical emergency equipment. RCD protected as part of patient areas.
LIFX-034	LIGHT: reading light, tamper proof, anti ligature, ceiling recessed	1	1	
ELBO-015	SWITCH: light, single	1	2	Outside room, lighting to have controlled switching to create low stimulus environment.