

Room Name	Shower - Accessible		Room Number SHAC
Revision	6		
Issue Date	18.01.2021		
BRIEFING			
Briefed Area	4.00 m ²		
Hours of Operation	24 Hours		
Occupancy	1 patient; 1-2 staff assisting as required		
Acoustics	Sound attenuation level high, Acoustic privacy is required.		
Remarks			
Description / Special Requirements	The Shower - Accessible provides a shower for use by patients, visitors or staff with disabilities (with or without assistance). If the Toilet - Accessible is located in a patient care area the nurse call system should be included and emergency release door hardware should be installed to allow staff access in an emergency. An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system. The entrance to the room should be flush with the adjoining floor for access in commode chairs/wheelchairs. Facilities for hand hygiene and PPE to be available nearby if this room is for patient use. The room shall comply with Australian Standard 1428.1. Signage with braille tactile nominating 'Accessible Shower' required		
SERVICES			
General Requirements	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING	<input type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input checked="" type="checkbox"/>	VENTILATION <input checked="" type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLFS-009	CEILING: plasterboard, water resistant, flush set, suspended, paint, washable	water resistant ceiling tiles are also acceptable
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	with privacy latch and emergency release
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
FLVY-009	FLOOR FINISH: vinyl, seamless, coved, wet area, non-slip	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	to be tiles if tiled floor
WLWA-019	WALL FINISH: vinyl, full height	tiles are also acceptable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-024	CHAIR: shower	3	1	
FQGE-011	CURTAIN: shower	3	1	optional, refer to local infection control policy
FIRT-045	GRAB RAIL: shower, horizontal and vertical	1	1	

Room Name | Shower - Accessible
Room Number SHAC

AusHFG code	Description	Group	Qty	Comment
FIDI-049	HOLDER: soap/shampoo, non-recessed	1	1	or soap dispenser
FIHR-026	HOOK: coat	1	2	
FIJO-194	SHELF: laminate	1	1	
HYTP-045	SHOWER: hand-held, accessible	1	1	
HYTP-039	TAPWARE: mixer, shower, lever action	1	1	
FIRT-033	TRACK: curtain, shower	1	1	optional, refer to local infection control policy

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	optional, IPX4 rating required
ITCL-006	BUTTON: nurse call, patient to staff	1	1	optional, IPX4 rating required
ITCL-008	BUTTON: nurse call, staff assist	1	1	optional, IPX4 rating required
HYDR-004	DRAIN: floor waste	1	1	
ELBO-015	SWITCH: light, single	1	1	