

Room Name | Shower - Decontamination, 8m2

Room Number SHDEC

Revision 3
Issue Date 20.03.17

BRIEFING
Briefed Area 8.00 m²
Hours of Operation 24 Hours
Occupancy 1 - 2
Acoustics
Remarks
Description / Special Requirements

The Decontamination Shower is provided to shower patients who arrive in the Unit contaminated with toxic and/or infectious substances. The room will include a flexible water hose, floor drain and contaminated water trap. The shower should be accessible from the ambulance bay without entering any other part of the Unit. A Personal Protective Equipment Bay may be located in close proximity.

SERVICES
General Requirements

BODY PROTECTED = No CARDIAC PROTECTED = No

Air

 AIRCONDITIONING = No AIRCONDITIONING: hepa filtered = No
 AIRCONDITIONING: positive pressure = No AIRCONDITIONING: negative pressure = No
 EXHAUST: room exhaust = Yes VENTILATION = Yes

Lighting

 LIGHTING: colour corrected = Yes LIGHTING: dimmable = No
 LIGHTING: downlights = No LIGHTING: downlights, dimmable = No
 LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No
 LIGHTING: fluorescent, general = No LIGHTING: indirect = No

Nurse Call

NURSE CALL SYSTEM = Yes

RETIRED

Room Fabrics

AusHFG code	Description	Comment
CLTI-014	CEILING: plasterboard, water resistant, drop-in tiles, prefinished, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	outward opening; privacy latch; emergency release; no. of doors to suit layout
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	equal to Acrovyn
FLVY-005	FLOOR FINISH: vinyl, seamless, coved, non slip, studded	tiles also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	or tiles for tiled floor
WLWA-019	WALL FINISH: vinyl, full height	to wet areas; tiles also acceptable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIDI-014	DISPENSER: disposable glove	2	2	
MMBE-025	GURNEY	3	1	
HYTP-017	SHOWER: decontamination	1	1	in lockable cabinet

Room Name | Shower - Decontamination, 8m2

Room Number SHDEC

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	
HYDR-001	DRAIN: special requirements	1	1	to contaminated water trap
MGAS-023	OUTLET: medical air (MA), wall mounted	1	1	in lockable recess, optional
MGAS-043	OUTLET: oxygen (O2), wall mounted	1	1	in lockable recess, optional
MGAS-063	OUTLET: suction, wall mounted	1	1	in lockable recess, optional
MMSP-026	SERVICES PANEL: wall mounted	2	1	recessed, lockable cover, if gases required
ELBO-015	SWITCH: light, single	1	2	

RETIRED