

Room Name	Shower - Patient		Room Number SHPT
Revision	6		
Issue Date	18.01.2021		
BRIEFING			
Briefed Area	4.00 m ²		
Hours of Operation	24 Hours		
Occupancy	1 patient; 1-2 staff assisting as required		
Acoustics	Sound attenuation level high, Acoustic privacy is required.		
Remarks			
Description / Special Requirements	The Shower - Patient provides a shower and basin for use by patients (with or without assistance). Emergency release door hardware should be installed to allow staff access in an emergency. The entrance to the room should be flush with the adjoining floor for access in commode chairs/wheelchairs. Signage with braille tactile nominating 'Patient Shower' required		
SERVICES			
General Requirements	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING	<input type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input checked="" type="checkbox"/>	VENTILATION <input checked="" type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLFS-009	CEILING: plasterboard, water resistant, flush set, suspended, paint, washable	water resistant ceiling tiles are also acceptable
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	with privacy latch and emergency release
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
FLVY-009	FLOOR FINISH: vinyl, seamless, coved, wet area, non-slip	to be suitable for bare feet; tiles are also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	to be tiles if tiled floor
WLWA-019	WALL FINISH: vinyl, full height	tiles are also acceptable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-011	BASIN: handwash, Type C	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	
MMGE-024	CHAIR: shower	3	1	or commode chair, optional
FQGE-011	CURTAIN: shower	3	1	optional, refer to local infection control policy

Room Name | Shower - Patient

Room Number SHPT

AusHFG code	Description	Group	Qty	Comment
FIDI-025	DISPENSER: paper/hand towel	2	1	
FIDI-030	DISPENSER: soap	2	1	to basin
FIRT-045	GRAB RAIL: shower, horizontal and vertical	1	1	
FIDI-049	HOLDER: soap/shampoo, non-recessed	1	1	or soap dispenser
FIHR-026	HOOK: coat	1	2	
FIBM-006	MIRROR: fixed, glass	1	1	
FIRT-016	RAIL: towel	1	1	with grab rail strength/fixings
HYTP-020	SHOWER: hand-held	1	1	
HYTP-036	TAPWARE: mixer, basin, lever action	1	1	
HYTP-039	TAPWARE: mixer, shower, lever action	1	1	
FIRT-034	TRACK: curtain, shower, 90 deg	1	1	optional, refer to local infection control policy

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	IPX4 rating required
ITCL-006	BUTTON: nurse call, patient to staff	1	1	IPX4 rating required
ITCL-008	BUTTON: nurse call, staff assist	1	1	IPX4 rating required
HYDR-004	DRAIN: floor waste	1	1	
ELGP-208	GPO: double, wall mounted	1	1	optional, to be classified as a shaver outlet or installed within a cupboard if provided
ELBO-015	SWITCH: light, single	1	1	IPX4 rating required