

Room Name	Specimen Collection Bay	Room Number SPECC
Revision	3	
Issue Date	20.03.17	
BRIEFING		
Briefed Area	9.00 m ²	
Hours of Operation	24 Hours	
Occupancy	1 patient; 1 staff member	
Acoustics		
Remarks		
Description / Special Requirements	A Patient Bay used for collection of specimens from patients. The Specimen Collection Bay will have close access to a staff handwashing basin.	
SERVICES		
General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
Lighting	LIGHTING: colour corrected = Yes LIGHTING: downlights = Yes LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
Nurse Call	NURSE CALL SYSTEM = No	

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	Drop in tile ceiling also acceptable
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	Equal to 'Acrovyn'
WLPR-019	WALL PROTECTION: crash rail, at 900 AFFL, prefinished PVC	Equal to 'Acrovyn'

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-011	BENCH: 450D, open under, laminate finish	1	1	small, 900mm high, for write-up
FQSN-006	BIN: storage bins, for wall mounted panel	3	1	for louvred panel
FQCW-044	BIN: waste, sharps, wall mounted	3	1	on trolley
FIHR-016	BRACKET: for sharps bin	2	1	on trolley
FQBS-022	CHAIR: recliner, clinical	3	1	or mobile trolley/ bed
FQGE-009	CURTAIN: bed screen	3	1	

Room Name | **Specimen Collection Bay**
Room Number **SPECC**

AusHFG code	Description	Group	Qty	Comment
FIDI-014	DISPENSER: disposable glove	2	1	
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	
FIHR-033	PANEL: for storage bins, wall mount	1	1	
FQBS-051	STOOL: mobile, adj height	3	1	staff use
FIRT-023	TRACK: curtain, bedscreen, L shaped	1	2	
MMGE-119	TROLLEY: equipment	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-209	GPO: double, wall mounted, RCD protected	1	1	
ELGP-123	GPO: emergency power, single, wall mounted	1	1	
ELGP-109	GPO: single, wall mounted	1	1	
ELGP-110	GPO: single, wall mounted, cleaner	1	1	as required
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	