# Australasian Health Facility Guidelines

**Room Data Sheet** 

Room Name	Specimen Reception/ Sort/ Preparation	Room Number SPREC				
Revision	3					
Issue Date	20.03.17					
BRIEFING						
Briefed Area	20.00 m <sup>2</sup>					
Hours of Operation	0800 Hours - 1800 or 2000 hours					
Occupancy	Up to 4 staff members, 3 seated workstations					
Acoustics						
Remarks						
Description / Special Requirements	A Reception area where specimens for analysis are received, sorted and held temporarily before despatch into laboratory areas. Additional Design Requirements: Security shutters or glazing may be required.					
0551/050						
SERVICES						
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No				
Air	AIRCONDITIONING = Yes	AIRCONDITIONING: hepa filtered = No				
	AIRCONDITIONING: positive pressure = No	AIRCONDITIONING: negative pressure = No				
	EXHAUST: room exhaust = No	VENTILATION = No				
Lighting	LIGHTING: colour corrected = No	LIGHTING: dimmable = No				
Lighting	LIGHTING: downlights = Yes	LIGHTING: downlights, dimmable = No				
	LIGHTING: fluorescent, downlights = No	LIGHTING: fluorescent, flush with ceiling, tamper proof = No				
	LIGHTING: fluorescent, general = Yes	LIGHTING: indirect = No				
Nurse Call	NURSE CALL SYSTEM = No					

#### **Room Fabrics**

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLGE-001	CEILING: plasterboard, bulkhead, paint	optional
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	lockable
DWPR-003	DOOR PROTECTION: kickplate, to 300 AFFL, vinyl, prefinished	
FLCP-003	FLOOR FINISH: carpet, broadloom, 48 oz., 90/10 wool/nylon	to front reception area
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	to sort/ preparation area
FLSK-009	SKIRTING: vinyl, feather edged, 150H, prefinished	to front reception area
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	to sort/ preparation area
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin & sorting bench, tiles also acceptable
WLPR-012	WALL PROTECTION: corner guards, to 900 AFFL, prefinished PVC	as required

## Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	



## Room Name Specimen Reception/ Sort/ Preparation

**Room Number SPREC** 

AusHFG code	Description	Group	Qty	Comment
FIJO-031	BENCH: 750D, open under, laminate finish	1	1	sorting work bench
FIJO-069	BENCH TOP: 750D, joinery under, laminate finish	1	1	sorting lab bench
FQCW-016	BIN: waste, general, 20L	3	1	
MMLA-036	CENTRIFUGE: benchtop	3	1	
FQBS-018	CHAIR: office, ergonomic	3	2	
FQBS-019	CHAIR: office, ergonomic, high	3	1	
ITNE-007	COMPUTER: desktop, with display screen	3	3	flat screen
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	1	under sorting lab bench
FIJO-143	CUPBOARD: wall mount, double door, adj shelves	1	3	over reception work bench
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	6	over sorting/ prepartion area benches
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
MMLA-054	FRIDGE: laboratory, floor standing	3	1	specimen holding
MMLA-061	INCUBATOR: laboratory	3	1	optional
FIJO-170	JOINERY UNIT: counter top and screen under	1	1	resinate/laminate, in front of reception desk
FIJO-182	JOINERY UNIT: reception desk	1	1	reception work bench; timber veneer finish also acceptable
FQDW-004	KEYBOARD SHELF: drop down, for workstation	1	3	optional
FIBM-013	NOTICEBOARD: fixed, fabric covered	1	2	to upstand of reception desk and over workstation bench
WLPT-003	PARTITION: laminate	1	1	under worktop
FQSM-007	PEDESTAL: mobile, drawer unit, 660H	3	2	under bench
ITNE-023	PRINTER: networked	3	1	
DWWH-004	SHUTTER: roller, manual	1	1	optional, may also use safety glass or 'Perspex/ Lexan' materials
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-049	TELEPHONE: handset, desktop	3	1	

## **Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	
ELGP-208	GPO: double, wall mounted	1	9	
ELGP-109	GPO: single, wall mounted	1	1	refrigerator
LIFX-031	LIGHT: downlight, recessed	1	1	to bulkhead, if provided
LIFX-008	LIGHT: task light, built in	1	2	to counter top & under O/H joinery
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	5	
ELBO-015	SWITCH: light, single	1	3	

