

Room Name	Store - Accountable Drugs	Room Number STAD
<b>Revision</b>	3	
<b>Issue Date</b>	20.03.17	
<b>BRIEFING</b>		
<b>Briefed Area</b>	5.00 m <sup>2</sup>	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	1 - 2 intermittently	
<b>Acoustics</b>		
<b>Remarks</b>		
<b>Description / Special Requirements</b>	<p>The Store - Accountable Drugs is a strongroom for storage of accountable (Schedule 8) drugs and medications, located within the Pharmacy Unit. Refrigerated storage may also be required. The strongroom will require adequate ventilation and a gate door for security when the main door is open. Accountable drugs storage facilities are to comply with NSW Health Pharmaceuticals Services Branch Policy and the requirements noted in the NSW Police Service document 'Minimising the Risks'. Additional Design Considerations: The strongroom should be independent of the rest of the building structure with no beams or columns passing through the ceiling, walls or floor. The ceiling, walls and floor should be constructed of concrete with a compressive strength of 70 m/p/a with either 1 cm thick tang bar or 1 cm thick reinforcing rods in three levels in a criss cross pattern. The ceiling, walls and floor should be a minimum thickness of 300mm. The door should be torch and drill resistant, fitted with a combination lock facility incorporating duress features and an internal release mechanism in case persons are trapped within. A torch and drill resistant breather tube must be fitted, to comply with Fire Regulations. Security detection equipment should be incorporated into the alarm system, to detect any attack on the structure. A telephone should be installed for staff safety; the telephone should be concealed to restrict unauthorised tampering.</p>	
<b>SERVICES</b>		
<b>General Requirements</b>	BODY PROTECTED = No	CARDIAC PROTECTED = No
<b>Air</b>	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = Yes
<b>Lighting</b>	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
<b>Nurse Call</b>	NURSE CALL SYSTEM = No	

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGE-002	DOOR: 910mm c/o, steel, strongroom, grille gate door, paint	inner door
DWGE-003	DOOR: 910mm c/o, steel, strongroom, security door, paint	Equal to 'Chubb' Pacific 100
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	
FIJO-128	CUPBOARD: tall, shelf unit, pharmacy shelves	3	2	

**Room Name | Store - Accountable Drugs**
**Room Number STAD**

AusHFG code	Description	Group	Qty	Comment
FIJO-142	CUPBOARD: underbench, single, adj shelves, with single drawer	1	1	drawer/ cupboard unit
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	2	
MMGE-036	FRIDGE: drugs, underbench	3	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	on bench, optional

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITSE-002	ALARM: duress	1	1	to entry lock mechanism
ITSE-004	ALARM: reed switch	1	1	to door and structure
ELGP-208	GPO: double, wall mounted	1	1	
ELGP-109	GPO: single, wall mounted	1	1	refrigerator
LIFX-008	LIGHT: task light, built in	1	1	under O/H shelving
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	1 outlet for telephone
ELBO-015	SWITCH: light, single	1	2	
MEGE-015	VENTILATION PORT	1	1	