

Room Name	Store - Accountable Drugs	Room Number STAD
Revision	4	
Issue Date	26.04.2021	
BRIEFING		
Briefed Area	7.50 m ²	
Hours of Operation	24 Hours	
Occupancy	1 - 2 intermittently	
Acoustics		
Remarks		
Description / Special Requirements	<p>The Store – Accountable Drugs is a strongroom located within the Pharmacy Unit for the storage of accountable (Schedule 8) drugs and medications and provides a secure caged area for assembling orders. This room is to comply with jurisdictional legislation and public health facility policy, including any special provisions for refrigerated medicines. The strong room should be designed in collaboration with an expert security consultant with assessment of the risks for the particular site.</p> <p>Additional Design Considerations:</p> <ul style="list-style-type: none"> The strong room should be independent of the rest of the building structure with no beams or columns passing through the ceiling, walls or floor. The ceiling walls and floor should be built utilising suitable construction methods, e.g. reinforced concrete or steel plate modular forms (the wall thickness shown in this Standard Component is indicative only). A gate door is to be provided for security when the main door is open. The security door should be torch and drill resistant, fitted with an appropriate locking mechanism incorporating duress features and an internal release mechanism in case persons are trapped within. The strongroom will require adequate ventilation and a torch and drill resistant breather tube must be fitted to comply with fire regulations. Security monitoring and detection equipment should be incorporated into the alarm system, to detect any attack on the structure. A telephone should be installed for staff safety 	
SERVICES		
Electrical	BODY PROTECTED <input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
HVAC	AIRCONDITIONING <input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure <input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust <input type="checkbox"/>	VENTILATION <input checked="" type="checkbox"/>
Lighting	LIGHTING: colour corrected <input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights <input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights <input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general <input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Security / Nurse Call	NURSE CALL SYSTEM <input type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGE-002	DOOR: 910mm c/o, steel, strongroom, grille gate door, paint	inner door; access and door release controls to be determined based on security strategy

Room Name | Store - Accountable Drugs
Room Number STAD

AusHFG code	Description	Comment
DWGE-003	DOOR: 910mm c/o, steel, strongroom, security door, paint	outer door; access and door release controls to be determined based on security strategy
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-023	WALL FINISH: vinyl, to 2100 AFFL	extent dependent on type and height storage solution

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
ITNE-003	BAR CODING: reader	3	1	
FIHR-002	BRACKET: for CCTV camera, ceiling mounted	1	1	
FIJO-212	BULKHEAD: joinery	1	1	
ITSE-012	CAMERA: CCTV	1	1	
FQBS-019	CHAIR: office, ergonomic, high	3	1	
ITNE-007	COMPUTER: desktop, with display screen	3	1	may be on wall or desk mounted bracket, an additional screen may be provided depending on project ICT requirements
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	1	
FQDW-051	DESK: adj height, 1500W x 600D x 900H nom.	3	1	
MMGE-034	FRIDGE: drugs, large	3	1	optional
FQSM-007	PEDESTAL: mobile, drawer unit, 660H	3	1	
FQGE-093	PRINTER: desktop, labels, pharmacy	3	1	
FQSM-048	SHELVING: storage solution, shelving, 600W x 400D x 2100H nom., wire, mobile	3	3	type and quantity of storage options to be determined based on service requirements
ITNE-049	TELEPHONE: handset, desktop	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-003	ALARM: intruder detection	1	1	to entry lock mechanism
ELGP-208	GPO: double, wall mounted	1	3	extent of emergency power to be determined based on service requirements
ELGP-223	GPO: emergency power, double, wall mounted	1	1	optional, for refrigerator if provided
LIFX-008	LIGHT: task light, built in	1	1	under wall mounted joinery
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	optional, temperature monitoring, for refrigerator if provided
ITSE-038	READER: access control, general	1	1	

Room Name | Store - Accountable Drugs

Room Number STAD

AusHFG code	Description	Group	Qty	Comment
ELBO-015	SWITCH: light, single	1	2	1 x general room lighting, 1 x task light
MEGE-015	VENTILATION PORT	1	2	