

**Room Name** | Store - Equipment, 20m2

**Room Number** STEQ-20

**Revision** 5  
**Issue Date** 20.03.17

**BRIEFING**
**Briefed Area** 20.00 m<sup>2</sup>  
**Hours of Operation** 24 Hours  
**Occupancy** 1 - 2 intermittently  
**Acoustics**  
**Remarks**
**Description / Special Requirements**

The Equipment Store is used for the storage of medical equipment when not in use and recharging of electrical items. Space is required for parking of mobile equipment including IV poles, wheelchairs, lifting equipment, trolleys, cradles and commode chairs for the Unit. Hooks will be required for hanging equipment.

**SERVICES**
**General Requirements**

BODY PROTECTED = No

CARDIAC PROTECTED = No

**Air**

 AIRCONDITIONING = Yes  
 AIRCONDITIONING: positive pressure = No  
 EXHAUST: room exhaust = No

 AIRCONDITIONING: hepa filtered = No  
 AIRCONDITIONING: negative pressure = No  
 VENTILATION = No

**Lighting**

 LIGHTING: colour corrected = No  
 LIGHTING: downlights = No  
 LIGHTING: fluorescent, downlights = No  
 LIGHTING: fluorescent, general = Yes

 LIGHTING: dimmable = No  
 LIGHTING: downlights, dimmable = No  
 LIGHTING: fluorescent, flush with ceiling, tamper proof = No  
 LIGHTING: indirect = No

**Nurse Call**

NURSE CALL SYSTEM = No

**Room Fabrics**

| AusHFG code | Description  | Comment  |
|-------------|--|----------|
| CLTI-008    | CEILING: plasterboard, drop-in tiles, prefinished, 600 x 1200    |          |
| CLCN-002    | CORNICE: aluminium, 24mm shadow angle, powdercoat                |          |
| DWSC-021    | DOOR: 1400mm c/o, 1 1/2 leaf, solid core, paint                  | lockable |
| DWPR-006    | DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished |          |
| DWPR-010    | DOOR PROTECTION: to door frame, PVC, prefinished                 |          |
| FLVY-007    | FLOOR FINISH: vinyl, seamless, coved, standard slip resistant    |          |
| FLSK-010    | SKIRTING: vinyl, floor vinyl coved, 150H, prefinished            |          |
| WLWA-004    | WALL FINISH: paint, acrylic, washable                            |          |
| WLPR-021    | WALL PROTECTION: crash rail, at 900 AFFL                         |          |

**Fittings, Furniture and Equipment (FF&E) Items**

| AusHFG code | Description   | Group | Qty | Comment                  |
|-------------|---|-------|-----|--------------------------|
| FIHR-030    | HOOK: equipment, on mounting plate                        | 1     | 4   | to support 10kg per hook |
| FIRT-012    | RAIL: equipment   | 1     | 1   |                          |
| FQSN-086    | SHELVING: floor standing, 900W x 400D x 2100H nom., metal | 3     | 5   |                          |
| FIBM-019    | WHITEBOARD: fixed, magnetic                               | 2     | 1   |                          |

Room Name | Store - Equipment, 20m2

Room Number STEQ-20

## Engineering Services

| AusHFG code | Description               | Group | Qty | Comment                  |
|-------------|---------------------------|-------|-----|--------------------------|
| ELGP-208    | GPO: double, wall mounted | 1     | 5   | for equipment recharging |
| ELBO-015    | SWITCH: light, single     | 1     | 1   |                          |