

Room Name	Stress Testing	Room Number	STRT
Revision	3		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	12.00 m ²		
Hours of Operation	Available 24 Hours		
Occupancy	1 patient; 1 - 2 staff		
Acoustics	Acoustic privacy is required		
Remarks			
Description / Special Requirements	Room for undertaking patient diagnostic stress testing procedures. The Stress Testing room should be located close to patient toilet and change rooms.		
SERVICES			
General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = Yes		

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	equal to Acrovyn
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin; tiles also acceptable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	refer to BHWS-B (similar)
MMAH-002	BICYCLE: exercise	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FQBS-014	CHAIR: client	3	1	
FQBS-018	CHAIR: office, ergonomic	3	1	

Room Name | Stress Testing
Room Number STRT

AusHFG code	Description	Group	Qty	Comment
FQGE-005	CLOCK: analogue, battery operated	3	1	
ITNE-007	COMPUTER: desktop, with display screen	3	1	
FQGE-010	CURTAIN: privacy screen	3	1	to entry door
FQDW-003	DESK: adj height, 800W x 900D x 750H nom., with shelf	3	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
FIHR-026	HOOK: coat	1	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-049	TELEPHONE: handset, desktop	3	1	to computer table
FIRT-032	TRACK: curtain, privacy, L shaped	1	1	to entry door
MMAH-027	TREADMILL: automatic	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	2	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ELGP-208	GPO: double, wall mounted	1	4	
ELGP-209	GPO: double, wall mounted, RCD protected	1	2	
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	2	call button on the handset
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	1 outlet for telephone
ELBO-015	SWITCH: light, single	1	1	