

Room Name	Stress Testing	Room Number	STRT
Revision	4		
Issue Date	13.05.2020		
BRIEFING			
Briefed Area	20.00 m ²		
Hours of Operation	Available 24 Hours		
Occupancy	1 patient; 1 - 2 staff		
Acoustics	Acoustic privacy is required		
Remarks			
Description / Special Requirements	Room for undertaking patient diagnostic stress testing procedures. The Stress Testing room should be located close to patient toilet and change rooms.		
SERVICES			
General Requirements	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWSC-021	DOOR: 1400mm c/o, 1 1/2 leaf, solid core, paint	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-025	WALL FINISH: vinyl, to 1200 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	2	
HYBA-010	BASIN: handwash, Type B	1	1	refer to BHWS-B (similar)

Room Name | Stress Testing
Room Number STRT

AusHFG code	Description	Group	Qty	Comment
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	
FQCW-005	BIN: waste, clinical, 20L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FIHR-019	BRACKET: for suction bottle	2	2	
FIJO-212	BULKHEAD: joinery	1	1	
FQBS-019	CHAIR: office, ergonomic, high	3	1	
FQBS-028	CHAIR: visitor, clinical areas	3	1	
ITCL-014	CLOCK: analogue, electric	1	1	
ITNE-071	COMPUTER: desktop, with dual display screens	3	1	
FIJO-131	CUPBOARD: tall, single door, adj shelves, lockable	1	1	
FQGE-010	CURTAIN: privacy screen	3	1	to entry door
MMHA-002	DEFIBRILLATOR	3	1	
MMMI-325	DEVICE: imaging, echocardiography machine	3	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-019	DISPENSER: gown/apron	2	1	
FIDI-021	DISPENSER: mask	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	optional
MGFP-004	FLOWMETER: oxygen	3	2	
FIHR-026	HOOK: coat	1	2	optional
LIFX-027	LIGHT: examination, ceiling mounted	1	1	
MMGE-048	LINEN CARRIER: dirty, single	3	1	
MMGE-179	MACHINE: electrocardiography (ECG), c/w trolley and printer shelf (PENDING PUBLICATION)	3	1	
FQSM-003	PEDESTAL: mobile, wire basket unit, 840H	3	2	
MMGE-088	SAFE: dangerous drugs, small	1	1	optional, for pharmacological stress testing
FQBS-052	STOOL: mobile, high, adj height	3	2	
MMGE-100	SUCTION BOTTLE	3	2	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-049	TELEPHONE: handset, desktop	3	1	
FIRT-023	TRACK: curtain, bedscreen, L shaped	1	1	
MMAH-027	TREADMILL: automatic	3	1	
MMBE-069	TROLLEY: patient, echocardiography	3	1	
MMHA-027	TROLLEY: resuscitation, adult	3	1	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	

Room Name | Stress Testing

Room Number STRT

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel, + indicator button & light
ELGP-208	GPO: double, wall mounted	1	6	
ELGP-223	GPO: emergency power, double, wall mounted	1	3	
ELGP-122.1	GPO: emergency power, single, on services panel (V)	1	4	on services panel
ELGP-101	GPO: single, ceiling mounted	1	1	
ELGP-109	GPO: single, wall mounted	1	1	
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	5	1 outlet for telephone
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	on services panel, optional
MGAS-042	OUTLET: oxygen (O2), on services panel	1	2	on services panel
MGAS-062	OUTLET: suction, on services panel	1	2	on services panel
ELPR-006	RCD: residual current device	1	2	
MMSP-026	SERVICES PANEL: wall mounted	1	1	
ELBO-012	SWITCH: light, dimmer	1	1	
ELBO-015	SWITCH: light, single	1	2	optional, to optional change room