

<b>Room Name</b>	<b>Store - Sterile Stock, 12m2</b>	<b>Room Number STSS-12</b>
<b>Revision</b>	4	
<b>Issue Date</b>	20.03.17	
<b>BRIEFING</b>		
<b>Briefed Area</b>	12.00 m <sup>2</sup>	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	1 - 2 intermittently	
<b>Acoustics</b>		
<b>Remarks</b>		
<b>Description / Special Requirements</b>	A room with an aseptic environment for storage and holding of sterile stock for use in the Operating Suite or other acute treatment areas. This room may also accommodate drugs in lockable cupboards and safe as required. Sterile stock may be stored in wire mesh shelving either static units, single mobile units or compactus. Structural Engineer's advice must be sought if compactus is to be used (floor load bearing capacity and potential deflection effect on walls, doors, etc). Size and number/type of shelving to be adapted to suit specific project briefing and OHS requirements as per AusHFG HPUs. Add 1m2 per 900w400d2100h shelving unit. Compactus units as per manufacturer's specifications.	
<b>SERVICES</b>		
<b>General Requirements</b>	BODY PROTECTED = No	CARDIAC PROTECTED = No
<b>Air</b>	AIRCONDITIONING = No AIRCONDITIONING: positive pressure = Yes EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = Yes AIRCONDITIONING: negative pressure = No VENTILATION = No
<b>Lighting</b>	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
<b>Nurse Call</b>	NURSE CALL SYSTEM = No	

RETIRED

**Room Fabrics**

AusHFG code	Description	Comment
CLGE-001	CEILING: plasterboard, bulkhead, paint	Between above bench joinery and ceiling.
CLFS-005	CEILING: plasterboard, flush set, suspended, paint, scrub resistant	
CLCN-007	CORNICE: plasterboard, flush covered between wall and ceiling, paint	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	Lockable.
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Optional. To be decided at project level.
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-005	WALL FINISH: paint, scrub resistant	
WLPR-011	WALL PROTECTION: corner guards, to 900 AFFL min.	
WLPR-021	WALL PROTECTION: crash rail, at 900 AFFL	

**Fittings, Furniture and Equipment (FF&E) Items**

**Room Name** | Store - Sterile Stock, 12m2

**Room Number** STSS-12

AusHFG code	Description	Group	Qty	Comment
FIJO-020	BENCH: 600D, open under, laminate finish	1	1	Optional. Length to suit, refer RLS or project specific requirements.
FQSM-015	SHELVING: stainless steel wire mesh, mobile	3	6	Or compactus top-track system, to be determined at project level.
ITBU-021	SYSTEM: barcode tracking	3	1	Optional. Depends on inventory control policy, if required.
ITNE-049	TELEPHONE: handset, desktop	3	1	Optional, to bench or wall mounted.
MMOP-093	TROLLEY: set-up	3	1	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	2	
LIFX-008	LIGHT: task light, built in	1	0	Optional
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ELBO-015	SWITCH: light, single	1	2	

# RETIRED