

| Room Name                                 | Store - Sterile Stock, 20m2   |                                     | Room Number STSS-20  |
|---|---|-------------------------------------|--|
| <b>Revision</b>                           | 4   |                                     |  |
| <b>Issue Date</b>                         | 02.07.2018  |                                     |  |
| <b>BRIEFING</b>                           |   |                                     |  |
| <b>Briefed Area</b>                       | 20.00 m <sup>2</sup>  |                                     |  |
| <b>Hours of Operation</b>                 | 24 hours  |                                     |  |
| <b>Occupancy</b>                          | Up to 3 intermittently  |                                     |  |
| <b>Acoustics</b>                          |   |                                     |  |
| <b>Remarks</b>                            |   |                                     |  |
| <b>Description / Special Requirements</b> | <p>A room with an aseptic environment for storage and holding of sterile stock for use in the Operating Suite or other acute treatment areas. Sterile stock may be stored in wire mesh shelving either static units, single mobile units or compactus. Structural engineering advice must be sought if compactus is to be used (floor load bearing capacity and potential deflection effect on walls, doors, etc). Top Track compactus may also be used. Size and number/type of shelving to be adapted to suit specific project briefing and WHS requirements as per AusHFG HPU's. Add 1m2 per 900w400d2100h shelving unit. Compactus units as per manufacturer specifications. Storage height to be limited to 520mm min below ceiling to meet Fire Sprinkler system requirements within AS2118.1. Light fixtures to be sealed.</p> |                                     |  |
| <b>SERVICES</b>                           |   |                                     |  |
| <b>General Requirements</b>               | BODY PROTECTED  | <input type="checkbox"/>            | CARDIAC PROTECTED <input type="checkbox"/>   |
| <b>Air</b>                                | AIRCONDITIONING   | <input type="checkbox"/>            | AIRCONDITIONING: hepa filtered <input checked="" type="checkbox"/>                   |
|   | AIRCONDITIONING: positive pressure  | <input checked="" type="checkbox"/> | AIRCONDITIONING: negative pressure <input type="checkbox"/>                          |
|   | EXHAUST: room exhaust   | <input type="checkbox"/>            | VENTILATION <input type="checkbox"/>   |
| <b>Lighting</b>                           | LIGHTING: colour corrected  | <input type="checkbox"/>            | LIGHTING: dimmable <input type="checkbox"/>  |
|   | LIGHTING: downlights  | <input type="checkbox"/>            | LIGHTING: downlights, dimmable <input type="checkbox"/>                              |
|   | LIGHTING: fluorescent/LED, downlights   | <input type="checkbox"/>            | LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/> |
|   | LIGHTING: fluorescent/LED, general  | <input checked="" type="checkbox"/> | LIGHTING: indirect <input type="checkbox"/>  |
| <b>Nurse Call</b>                         | NURSE CALL SYSTEM   | <input type="checkbox"/>            |  |

**Room Fabrics**

| AusHFG code | Description  | Comment   |
|-------------|--|---|
| CLFS-005    | CEILING: plasterboard, flush set, suspended, paint, scrub resistant      |   |
| CLCN-008    | CORNICE: square set flush between wall and ceiling, paint                |   |
| DWGL-011    | DOOR: 950mm c/o, single leaf, observation panel, solid core/glass, paint | auto release, interlock   |
| DWPR-011    | DOOR PROTECTION: protection plate, to full height                        | auto release, interlock between door to corridor and door to operating room |
| DWPR-010    | DOOR PROTECTION: to door frame, PVC, prefinished                         | optional  |
| FLVY-007    | FLOOR FINISH: vinyl, seamless, coved, standard slip resistant            |   |
| FLSK-010    | SKIRTING: vinyl, floor vinyl coved, 150H, prefinished                    |   |
| WLWA-005    | WALL FINISH: paint, scrub resistant                                      |   |
| WLWA-023    | WALL FINISH: vinyl, to 2100 AFFL   |   |

**Fittings, Furniture and Equipment (FF&E) Items**

| AusHFG code | Description                              | Group | Qty | Comment |
|-------------|--|-------|-----|---------|
| FIJO-013    | BENCH: 450D, open under, stainless steel | 1     | 1   |         |

**Room Name | Store - Sterile Stock, 20m2**
**Room Number STSS-20**

| AusHFG code | Description  | Group | Qty | Comment  |
|-------------|--|-------|-----|--|
| FIHR-065    | BRACKET: for bench, 450D, wall mounted                             | 1     | 2   |  |
| FIHR-066    | BRACKET: for display screen, wall mounted, articulated, adj height | 2     | 1   |  |
| ITCL-018    | CLOCK: clock system slave, digital                                 | 1     | 1   | mount flush with wall  |
| ITNE-066    | COMPUTER: all-in-one, wall mounted                                 | 3     | 1   |  |
| ITNE-067    | KEYBOARD: keyboard and mouse only                                  | 3     | 1   |  |
| FQSM-042    | SHELVING: stainless steel wire mesh, for sutures, mobile           | 3     | 1   |  |
| FQSM-015    | SHELVING: stainless steel wire mesh, mobile                        | 3     | 6   | compactus top-track system is an optional alternative, to be determined at project level |
| FQBS-052    | STOOL: mobile, high, adj height                                    | 3     | 1   |  |
| ITBU-021    | SYSTEM: barcode tracking   | 3     | 1   | optional, depends on inventory control policy, if required                               |
| ITNE-049    | TELEPHONE: handset, desktop  | 3     | 1   | optional, to bench or wall mounted   |
| MMGE-138    | TROLLEY: preparation   | 3     | 4   |  |
| FIBM-019    | WHITEBOARD: fixed, magnetic  | 2     | 1   | optional   |

**Engineering Services**

| AusHFG code | Description                                     | Group | Qty | Comment   |
|-------------|---|-------|-----|---|
| ITSE-025    | DOOR RELEASE: access control, remote activation | 1     | 3   |   |
| ELGP-208    | GPO: double, wall mounted                       | 1     | 1   |   |
| ELGP-223    | GPO: emergency power, double, wall mounted      | 1     | 2   |   |
| LIFX-003    | LIGHT: illuminated sign, "Laser in Use"         | 1     | 2   |   |
| LIFX-002    | LIGHT: illuminated sign, "X-Ray in Use"         | 1     | 2   | wording on light to jurisdictional requirements |
| ITIN-036    | OUTLET: data, triple RJ45, wall mounted         | 1     | 1   |   |
| ELBO-015    | SWITCH: light, single                           | 1     | 3   |   |