

Room Name	Store - Sterile Stock, Central Core	Room Number STSS-CC
Revision	1	
Issue Date	02.07.2018	
BRIEFING		
Briefed Area	34.00 m ²	
Hours of Operation	24 hours	
Occupancy	Up to 3 intermittently	
Acoustics		
Remarks		
Description / Special Requirements	A room with an aseptic environment for storage and holding of sterile stock for use in the Operating Suite or other acute treatment areas. Sterile stock may be stored in wire mesh shelving either static units, single mobile units or compactus. Structural engineering advice must be sought if compactus is to be used (floor load bearing capacity and potential deflection effect on walls, doors, etc). Top Track compactus may also be used. Size and number/type of shelving to be adapted to suit specific project briefing and WHS requirements as per AusHFG HPU's. Add 1m2 per 900w400d2100h shelving unit. Compactus units as per manufacturer specifications. Storage height to be limited to 520mm min below ceiling to meet Fire Sprinkler system requirements within AS 2118.1. Light fixtures to be sealed.	
SERVICES		
General Requirements	BODY PROTECTED <input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING <input type="checkbox"/>	AIRCONDITIONING: hepa filtered <input checked="" type="checkbox"/>
	AIRCONDITIONING: positive pressure <input checked="" type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust <input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected <input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights <input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights <input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general <input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM <input type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLFS-005	CEILING: plasterboard, flush set, suspended, paint, scrub resistant	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGL-011	DOOR: 950mm c/o, single leaf, observation panel, solid core/glass, paint	auto release, interlock
DWPR-011	DOOR PROTECTION: protection plate, to full height	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-005	WALL FINISH: paint, scrub resistant	
WLWA-023	WALL FINISH: vinyl, to 2100 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-013	BENCH: 450D, open under, stainless steel	1	1	
FIHR-065	BRACKET: for bench, 450D, wall mounted	1	2	

Room Name | **Store - Sterile Stock, Central Core**
Room Number STSS-CC

AusHFG code	Description	Group	Qty	Comment
FIHR-066	BRACKET: for display screen, wall mounted, articulated, adj height	2	1	
ITCL-018	CLOCK: clock system slave, digital	1	1	mount flush with wall
ITNE-066	COMPUTER: all-in-one, wall mounted	3	1	
ITNE-067	KEYBOARD: keyboard and mouse only	3	1	
FQSM-042	SHELVING: stainless steel wire mesh, for sutures, mobile	3	1	
FQSM-015	SHELVING: stainless steel wire mesh, mobile	3	15	or compactus top-track system, to be determined at project level
FQBS-052	STOOL: mobile, high, adj height	3	1	
ITBU-021	SYSTEM: barcode tracking	3	1	optional, depends on inventory control policy, if required
ITNE-049	TELEPHONE: handset, desktop	3	1	optional, to bench or wall mounted
MMGE-138	TROLLEY: preparation	3	3	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	optional

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-025	DOOR RELEASE: access control, remote activation	1	2	
ELGP-208	GPO: double, wall mounted	1	2	
ELGP-223	GPO: emergency power, double, wall mounted	1	2	to benchtop
LIFX-003	LIGHT: illuminated sign, "Laser in Use"	1	2	
LIFX-002	LIGHT: illuminated sign, "X-Ray in Use"	1	2	wording on light to jurisdictional requirements
ITIN-036	OUTLET: data, triple RJ45, wall mounted	1	1	
ELBO-015	SWITCH: light, single	1	2	