

Room Name	Triage Assessment Room, Emergency - Type 1	Room Number	TRIAGE-1
<b>Revision</b>	1		
<b>Issue Date</b>	29.05.2019		
<b>BRIEFING</b>			
<b>Briefed Area</b>	13.00 m <sup>2</sup>		
<b>Hours of Operation</b>	24 Hours		
<b>Occupancy</b>	1 patient; 1 staff, 1 support person		
<b>Acoustics</b>	Sound attenuation level high, Acoustic privacy is essential.		
<b>Remarks</b>			
<b>Description / Special Requirements</b>	The Triage Room, Type 1 will provide a private area for initial assessment, physical examination and commencement of first aid of patients presenting to the Emergency Unit. The Triage Room, Type 1 is for smaller Emergency Units, where the room acts as both the initial triage and follow-on triage assessment requiring physical examination. The desk location and glazing arrangements support this dual function. Weighing facilities, including baby weighing, should be provided nearby. Negative pressure requirement indicates general directional airflow only. Air conditioning to be non recirculating.		
<b>SERVICES</b>			
<b>General Requirements</b>	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
<b>Air</b>	AIRCONDITIONING	<input type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input checked="" type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
<b>Lighting</b>	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
<b>Nurse Call</b>	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>	

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-003	DOOR: 910mm c/o, single leaf, half glazed, solid core/safety glass, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	
WLWA-025	WALL FINISH: vinyl, to 1200 AFFL	
WLPR-011	WALL PROTECTION: corner guards, to 900 AFFL min.	

**Fittings, Furniture and Equipment (FF&E) Items**

**Room Name | Triage Assessment Room, Emergency - Type 1**
**Room Number TRIAGE-1**

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	
HYBA-010	BASIN: handwash, Type B	1	1	
FQCW-005	BIN: waste, clinical, 20L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	1 to basin, 1 to desk
FQCW-044	BIN: waste, sharps, wall mounted	3	1	wall mounted
FIHR-011	BRACKET: for monitor, wall mounted	2	1	
FIHR-016	BRACKET: for sharps bin	2	1	
FIHR-019	BRACKET: for suction bottle	2	1	
FQBS-018	CHAIR: office, ergonomic	3	1	
FQBS-028	CHAIR: visitor, clinical areas	3	1	consider weight capacity of chair
ITNE-007	COMPUTER: desktop, with display screen	3	1	
FQGE-010	CURTAIN: privacy screen	3	3	to internal window as required
MMGE-031	DIAGNOSTIC SET: wall mounted	2	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-003	DISPENSER: bedroll	2	1	or provided as an attachment to exam couch
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	1	
FIHR-026	HOOK: coat	1	2	optional
LIFX-026	LIGHT: examination, wall mounted	1	1	
MMHA-005	MONITOR: patient, cardiac	3	1	
WLPT-012	SCREEN: security, safety glass, with communication slot	1	1	
FIJO-194	SHELF: laminate	1	1	to observation window
MMGE-100	SUCTION BOTTLE	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	
FIRT-031	TRACK: curtain, privacy	1	2	to staff access doorway and internal window as required
FIRT-032	TRACK: curtain, privacy, L shaped	1	1	to patient access door
FQSM-016	TROLLEY	3	1	
MMBE-044	TROLLEY: patient, transport	3	1	
FQDW-028	WORKSTATION: straight, adj height, 1200W x 750D x 750H nom.	3	1	

**Engineering Services**

**Room Name** | Triage Assessment Room, Emergency - Type 1

**Room Number** TRIAGE-1

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	in discreet location easily accessible by staff
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ITSE-025	DOOR RELEASE: access control, remote activation	1	1	
ELGP-223	GPO: emergency power, double, wall mounted	1	2	
ELGP-122	GPO: emergency power, single, on services panel	1	4	
ELGP-123	GPO: emergency power, single, wall mounted	1	2	
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ELGP-130	GPO: UPS, single	1	1	
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	1 outlet for telephone
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	
MGAS-062	OUTLET: suction, on services panel	1	1	
ELPR-006	RCD: residual current device	1	1	to services panel
ITSE-038	READER: access control, general	1	1	
MMSP-026	SERVICES PANEL: wall mounted	1	2	
ELBO-015	SWITCH: light, single	1	2	