

Room Name	Triage Assessment Room, Emergency - Type 2		Room Number	TRIAGE-2
Revision	1			
Issue Date	29.05.2019			
BRIEFING				
Briefed Area	13.00 m ²			
Hours of Operation	24 Hours			
Occupancy	1 patient; 1 staff, 1 support person			
Acoustics	Sound attenuation level high, Acoustic privacy is essential.			
Remarks				
Description / Special Requirements	The Triage Room, Type 2 will provide a private area for initial assessment, physical examination and commencement of first aid of patients presenting to the Emergency Unit. The Triage Room, Type 2 is for Emergency Units that also maintain a separate triage reception function. The room will be located adjacent to, or in close proximity to the triage reception function. Weighing facilities, including baby weighing, should be located nearby. Negative pressure requirement indicates general directional airflow only. Air conditioning to be non recirculating.			
SERVICES				
General Requirements	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED	<input type="checkbox"/>
Air	AIRCONDITIONING	<input type="checkbox"/>	AIRCONDITIONING: hepa filtered	<input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input checked="" type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION	<input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable	<input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect	<input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>		

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-003	DOOR: 910mm c/o, single leaf, half glazed, solid core/safety glass, paint	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	optional, to reception
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional, to reception door
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin
DWOB-007	OBSERVATION: internal window, alum/safety glass, powdercoat/paint	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	
WLWA-025	WALL FINISH: vinyl, to 1200 AFFL	
WLPR-011	WALL PROTECTION: corner guards, to 900 AFFL min.	

Room Name | Triage Assessment Room, Emergency - Type 2
Room Number TRIAGE-2
Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	
HYBA-010	BASIN: handwash, Type B	1	1	
FQCW-005	BIN: waste, clinical, 20L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	1 to basin, 1 to desk
FQCW-044	BIN: waste, sharps, wall mounted	3	1	wall mounted
FIHR-011	BRACKET: for monitor, wall mounted	2	1	
FIHR-016	BRACKET: for sharps bin	2	1	
FIHR-019	BRACKET: for suction bottle	2	1	
FQBS-019	CHAIR: office, ergonomic, high	3	1	
FQBS-028	CHAIR: visitor, clinical areas	3	1	consider weight capacity of chair
ITNE-008	COMPUTER: for workstation on wheels	3	1	
FQGE-010	CURTAIN: privacy screen	3	3	to internal window as required
MMGE-031	DIAGNOSTIC SET: wall mounted	2	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-003	DISPENSER: bedroll	2	1	or provided as an attachment to exam couch
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	1	
FIHR-026	HOOK: coat	1	2	optional
LIFX-026	LIGHT: examination, wall mounted	1	1	
MMHA-005	MONITOR: patient, cardiac	3	1	
MMGE-100	SUCTION BOTTLE	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
ITNE-053	TELEPHONE: handset, wall mount, handsfree	3	1	
FIRT-031	TRACK: curtain, privacy	1	2	to internal window as required
FIRT-032	TRACK: curtain, privacy, L shaped	1	1	
FQSM-016	TROLLEY	3	1	
MMBE-044	TROLLEY: patient, transport	3	1	
MMGE-164	WORKSTATION ON WHEELS: clinical, mobile	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	in discreet location easily accessible by staff

Room Name | Triage Assessment Room, Emergency - Type 2

Room Number TRIAGE-2

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ITSE-025	DOOR RELEASE: access control, remote activation	1	1	
ELGP-223	GPO: emergency power, double, wall mounted	1	1	to WOW
ELGP-122	GPO: emergency power, single, on services panel	1	4	
ELGP-123	GPO: emergency power, single, wall mounted	1	2	
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ELGP-130	GPO: UPS, single	1	1	
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	2	
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	
MGAS-062	OUTLET: suction, on services panel	1	1	
ELPR-006	RCD: residual current device	1	1	to services panel
ITSE-038	READER: access control, general	1	1	
MMSP-026	SERVICES PANEL: wall mounted	1	2	
ELBO-015	SWITCH: light, single	1	2	