

Room Name	Treatment Bay - Chemotherapy, 9m2		Room Number TRMT-CHE
<b>Revision</b>	3		
<b>Issue Date</b>	20.03.17		
<b>BRIEFING</b>			
<b>Briefed Area</b>	9.00 m <sup>2</sup>		
<b>Hours of Operation</b>	0800 Hours to 1800 Hours, daily		
<b>Occupancy</b>	1 patient, 1 support person, 1 staff assisting		
<b>Acoustics</b>			
<b>Remarks</b>			
<b>Description / Special Requirements</b>	The Treatment Bay - Chemotherapy is used for day treatment of patients undergoing cytotoxic treatments. A staff handwashing basin will be provided for each 4 bays (refer to Bay-Handwashing Type B for basin).		
<b>SERVICES</b>			
<b>General Requirements</b>	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
<b>Air</b>	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
<b>Lighting</b>	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
<b>Nurse Call</b>	NURSE CALL SYSTEM = Yes		

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin, tiles also acceptable
WLPR-002	WALL PROTECTION: bed protection wall panel, composite, laminate finish	
DWWH-005	WINDOW	Desirable

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	1 between 2 bays
MMBE-014	BED: patient, ICU, electric with mattress	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	
DWWD-006	BLIND: venetian	3	1	to external windows
FIHR-004	BRACKET: for display screen, ceiling mounted	1	1	to each bay
FIHR-016	BRACKET: for sharps bin	2	1	

**Room Name | Treatment Bay - Chemotherapy, 9m2**
**Room Number TRMT-CHE**

AusHFG code	Description	Group	Qty	Comment
FIHR-019	BRACKET: for suction bottle	2	1	1 between 2 bays
FQBS-023	CHAIR: recliner, clinical with attached side table	3	1	or patient bed
FQBS-030	CHAIR: visitor, patient	3	1	
FQGE-009	CURTAIN: bed screen	3	1	
ITBU-012	DISPLAY SCREEN: patient entertainment system	1	1	to each bay
MGFP-002	FLOWMETER: medical air	3	1	1 between 2 bays
MGFP-004	FLOWMETER: oxygen	3	1	1 between 2 bays
LIPO-006	LIGHT: examination, mobile	3	1	
FIJO-194	SHELF: laminate	1	1	for equipment
FQBS-051	STOOL: mobile, adj height	3	1	
MMGE-100	SUCTION BOTTLE	3	1	1 between 2 bays
FQTA-013	TABLE: overbed	3	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	optional
FIRT-023	TRACK: curtain, bedscreen, L shaped	1	1	
MMGE-119	TROLLEY: equipment	3	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light; shared for 4 bays
ITCL-006	BUTTON: nurse call, patient to staff	1	1	+ indicator button & light, 1 per bay
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light, 1 per bay
ELGP-206	GPO: double, on services panel, RCD protected	1	1	
ELGP-122	GPO: emergency power, single, on services panel	1	1	
ELGP-101	GPO: single, ceiling mounted	1	1	for display screen (TV)
ELGP-105	GPO: single, on services panel	1	3	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	call button on the handset, 1 per bay
LIFX-011	LIGHT: reading light	1	1	
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	1 per bay
ITIN-070	OUTLET: MATV	1	1	
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	on medical gas panel, 1 per 2 bays
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	on medical gas panel, 1 per 2 bays
MGAS-062	OUTLET: suction, on services panel	1	1	on medical gas panel, 1 per 2 bays