

Room Name | Treatment Room

Room Number: TRMT

Last modified	01/03/2016
Briefed Area	14.00
Remarks	
Occupancy	1 patient; 1-2 staff
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours
Acoustics	Sound attenuation level high, Acoustic privacy is required.
Description or Special Requirements	The Treatment Room provides a controlled environment, privacy and facilities for carrying out consultations, examinations and minor procedures. Acoustics: Sound attenuation level - high; Acoustic privacy is required. Body Protected electrical area

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
2726	Floor finish	Vinyl, non slip		Seamless coved	
3000	Wall finish	Paint	Acrylic, washable		
2727	Wall finish			Splashback	
2525	Wall protection			Bed protection wall panel	
5007	Ceiling - Plasterboard	Plasterboard	Paint	Bulkhead	
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
9128	Door - 1200mm	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel	1400mm clear opening; lockable
9004	Door - 1100mm	Solid Core/ Glass	Paint	Single leaf, observation panel	910mm clear opening, to Clean Utility, optional
2529	Door protection	Composite	Prefinished PVC	To door frame	
2712	Door protection			Protection plate to 900 AFFL	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1050	Bench - laminate	1	1	optional
FF-12900	Wire panel - for storage-bins	1	2	over bench, optional
FF-1465	Bracket - suction bottle	2	1	
FF-150	Air flowmeter	3	1	to services panel
FF-16250	Oxygen flowmeter	3	2	to services panel
FF-19700	Sharps bin	3	1	on trolley
FF-21755	Storage bins	3	5	for louvred panels, optional
FF-21950	Suction adapter	3	1	to services panel
FF-24100	Waste bin - paper, 20 Litre	3	1	to basin

Room Name | Treatment Room

Room Number: TRMT

AusHFG code	Description	Group	Qty	Comments
FF-3350	Clock - battery operated	3	1	
FF-4410	Cupboard - under bench	1	1	adjustable shelf, optional
FF-4470	Cupboard - wall mounted, lockable	1	1	over bench, adjustable shelf, optional
FF-4600	Curtain track - bed screen	1	1	to door opening
FF-5000	Curtain - bed screen	3	1	
FF-6152	Dispenser - disposable glove	2	1	3 compartments
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-6157	Dispenser - medicated hand gel	2	1	
FF-6158	Dispenser - soap antiseptic	2	1	to basin
FF-6600	Trolley - dressing	3	1	600x600x900mmH

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-11415	Computer - PACS	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	optional
FE-3100	Basin - scrub, Type A	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	refer to BHWS-A (sim)
FE-31700	Light - examination, ceiling	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-3700	Bed - inpatient, electric	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	spatial provision only
FE-43800	Refrigerator - under-bench, 120 Litre	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	optional
FE-54510	Telephone - handset, standard	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	to bench, optional
FE-68700	Xray viewer - 2 screen	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	optional

Service Requirements

Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	2	Bedhead low level, for electric bed
S-9000	GPO: Single	1	4	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	2	monitor
S-9001	GPO: Double	1	1	
S-9015	GPO: Cleaner	1	1	

Room Name | Treatment Room

Room Number: TRMT

AusHFG code	Description	Group	Qty	Comments
S-9040	Body protected	1	1	
S-9060	GPO: Special: for equipment	1	1	TV, ceiling
S-1006	Voice / Data outlet: double	1	2	1 outlet for telephone
S-5000	Airconditioning	1	1	
S-6001	General: colour corrected	1	1	
S-6055	Special: task light, built in	1	1	under O/H cupboards
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8005	Patient call handset	1	1	call button & light switch on the handset
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-7000	Oxygen (O2)	1	2	
S-7020	Medical Air (MA)	1	1	
S-7040	Suction	1	1	
S-11000	Wall panel	2	1	patient services panels