

Room Name	Treatment Room, 14m2		Room Number TRMT
Revision	5		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	14.00 m ²		
Hours of Operation	24 Hours		
Occupancy	1 patient; 1-2 staff		
Acoustics	Sound attenuation level high, Acoustic privacy is required.		
Remarks			
Description / Special Requirements	The Treatment Room provides a controlled environment, privacy and facilities for carrying out consultations, examinations and minor procedures.		
SERVICES			
General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = Yes		

Room Fabrics

AusHFG code	Description	Comment
CLGE-001	CEILING: plasterboard, bulkhead, paint	
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-033	DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	lockable
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	to Clean Utility, optional
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	
FLVY-006	FLOOR FINISH: vinyl, seamless, coved, non slip, textured	to basin
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	
WLPR-001	WALL PROTECTION: bed protection wall panel	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	to services panel

Room Name | Treatment Room, 14m2
Room Number TRMT

AusHFG code	Description	Group	Qty	Comment
HYBA-009	BASIN: handwash, Type A, scrub	1	1	
MMBE-009	BED: patient, electric	3	1	spatial provision only
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	optional
FQSN-006	BIN: storage bins, for wall mounted panel	3	12	for louvred panels, optional
FQCW-004	BIN: waste, clinical, 120L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-043	BIN: waste, sharps, on trolley	3	1	
FIHR-005	BRACKET: for display screen, PACS, wall mounted	3	1	optional, in place of shelf
FIHR-016	BRACKET: for sharps bin	2	1	
FIHR-019	BRACKET: for suction bottle	2	1	
MMGE-019	CHAIR: patient	3	1	
FQGE-005	CLOCK: analogue, battery operated	3	1	
ITNE-009	COMPUTER: hi performance, for clinical / PACS use	3	1	optional
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	1	optional
FIJO-140	CUPBOARD: underbench, single door, adj shelves	1	1	optional
FIJO-145	CUPBOARD: wall mount, double door, adj shelves, lockable	1	1	optional
FIJO-157	CUPBOARD: wall mount, single door, adj shelves, lockable	1	1	optional
FQGE-009	CURTAIN: bed screen	3	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	3 compartments
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	to services panel
MGFP-004	FLOWMETER: oxygen	3	2	to services panel
MMGE-036	FRIDGE: drugs, underbench	3	1	optional
FIHR-026	HOOK: coat	1	2	
LIFX-027	LIGHT: examination, ceiling mounted	1	1	
FIHR-033	PANEL: for storage bins, wall mount	1	2	over bench, optional
FIJO-194	SHELF: laminate	1	1	for PACS computer, optional
FQBS-052	STOOL: mobile, high, adj height	3	1	
MMGE-100	SUCTION BOTTLE	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-049	TELEPHONE: handset, desktop	3	1	to bench, optional
FIRT-023	TRACK: curtain, bedscreen, L shaped	1	1	To door opening
MMGE-113	TROLLEY: dressing	3	1	600x600x900mmH
MMGE-152	VIEWER: X-ray, 2 screen	1	1	optional

Room Name | Treatment Room, 14m2

Room Number TRMT

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	optional
ITCL-004	BUTTON: nurse call, emergency	1	1	on services panel + indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on services panel + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel + indicator button & light
ELGP-208	GPO: double, wall mounted	1	1	to bench
ELGP-209	GPO: double, wall mounted, RCD protected	1	1	
ELGP-122	GPO: emergency power, single, on services panel	1	2	on services panel
ELGP-101	GPO: single, ceiling mounted	1	1	exam light
ELGP-105	GPO: single, on services panel	1	4	on services panel
ELGP-109	GPO: single, wall mounted	1	2	optional, for XRV, fridge
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	on services panel, call button on the handset
LIFX-008	LIGHT: task light, built in	1	1	under O/H cupboards
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	on services panel
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	1 outlet for telephone
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	for computer, optional
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	on services panel
MGAS-042	OUTLET: oxygen (O2), on services panel	1	2	on services panel
MGAS-062	OUTLET: suction, on services panel	1	1	on services panel
MMSP-026	SERVICES PANEL: wall mounted	2	1	
ELBO-015	SWITCH: light, single	1	1	on services panel