

Room Name	Treatment Room	Room Number TRMT
<b>Revision</b>	6	
<b>Issue Date</b>	18.01.2021	
<b>BRIEFING</b>		
<b>Briefed Area</b>	14.00 m <sup>2</sup>	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	1 patient; 1-2 staff	
<b>Acoustics</b>	Sound attenuation level high, Acoustic privacy is required.	
<b>Remarks</b>		
<b>Description / Special Requirements</b>	The Treatment Room provides a controlled environment, privacy and facilities for carrying out consultations, examinations, treatments and minor procedures.	
<b>SERVICES</b>		
<b>General Requirements</b>	BODY PROTECTED <input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
<b>Air</b>	AIRCONDITIONING <input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure <input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust <input type="checkbox"/>	VENTILATION <input type="checkbox"/>
<b>Lighting</b>	LIGHTING: colour corrected <input checked="" type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights <input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights <input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general <input type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
<b>Nurse Call</b>	NURSE CALL SYSTEM <input checked="" type="checkbox"/>	

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGL-033	DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin or inset section of non-slip vinyl required
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	to basin
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	

**Room Name | Treatment Room**
**Room Number TRMT**

AusHFG code	Description	Group	Qty	Comment
HYBA-009	BASIN: handwash, Type A, scrub	1	1	
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	
FQCW-008	BIN: waste, clinical, 50L	3	1	optional; type, size and quantity of bins to be determined based on service requirements and waste management policies
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-043	BIN: waste, sharps, on trolley	3	1	
FIHR-016	BRACKET: for sharps bin	2	1	
FIHR-019	BRACKET: for suction bottle	2	1	
FIJO-212	BULKHEAD: joinery	1	1	plasterboard bulkhead also acceptable
FQGE-005	CLOCK: analogue, battery operated	3	1	
ITNE-008	COMPUTER: for workstation on wheels	3	1	computer may alternatively be on benchtop or wall mounted; allocation of WOWs across department to be rationalised
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	1	
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	1	
FQGE-010	CURTAIN: privacy screen	3	1	
MMGE-031	DIAGNOSTIC SET: wall mounted	2	1	optional, may be portable/mobile on stand
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	to basin
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	1	
FIHR-026	HOOK: coat	1	2	optional
LIFX-027	LIGHT: examination, ceiling mounted	1	1	
ITNE-023	PRINTER: networked	3	1	optional
FQBS-052	STOOL: mobile, high, adj height	3	1	
MMGE-100	SUCTION BOTTLE	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
ITNE-053	TELEPHONE: handset, wall mount, handsfree	3	1	
FIRT-032	TRACK: curtain, privacy, L shaped	1	1	
MMGE-119	TROLLEY: equipment	3	1	
MMBE-043	TROLLEY: patient, examination	3	1	
MMGE-164	WORKSTATION ON WHEELS: clinical, mobile	3	1	computer may alternatively be on benchtop or wall mounted; allocation of WOWs across department to be rationalised

Room Name | Treatment Room

Room Number TRMT

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on services panel + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel + indicator button & light
ELGP-208	GPO: double, wall mounted	1	2	
ELGP-122	GPO: emergency power, single, on services panel	1	2	
ELGP-101	GPO: single, ceiling mounted	1	1	to exam light
ELGP-105	GPO: single, on services panel	1	3	
ELGP-109	GPO: single, wall mounted	1	1	low level, for patient trolley
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	on services panel, call button on the handset
LIFX-008	LIGHT: task light, built in	1	1	under wall mounted joinery
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	to telephone
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	
MGAS-062	OUTLET: suction, on services panel	1	1	
ELPR-006	RCD: residual current device	1	4	
MMSP-026	SERVICES PANEL: wall mounted	1	1	
ELBO-015	SWITCH: light, single	1	3	1 x general room lighting, 1 x task light, 1 x examination light