

Room Name	Ultrasound Room - Procedures		Room Number	ULTR-PR
Revision	1			
Issue Date	29.05.2019			
BRIEFING	<div>The use of nitrous oxide in operating theatres, procedural suites and emergency departments is declining due to a range of clinical and environmental concerns. It is, however, still commonly used in maternity and paediatric services. With the exception of maternity and paediatric services, reticulated nitrous oxide and associated scavenge outlets are to be considered optional. Where found to be clinically necessary, provision of nitrous oxide via piped outlets or via cylinder is to be determined at a project level, based on an assessment of expected clinical needs, security of gas sources, operational considerations such as monitoring and measurement of usage, and management of leakage.</div>			
Briefed Area				
Hours of Operation				
Occupancy				
Acoustics				
Remarks				
Description / Special Requirements	Room for diagnostic ultrasound procedures such as breast biopsy, located close to patient toilet and change rooms. The room will require access for patients on hospital beds.			
SERVICES				
General Requirements	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED	<input type="checkbox"/>
Air	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered	<input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION	<input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable	<input checked="" type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect	<input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>		

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWSC-021	DOOR: 1400mm c/o, 1 1/2 leaf, solid core, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-010	WALL FINISH: splashback, vinyl	to basin; selection of material to comply with AHFG Part D Infection Control
WLWA-019	WALL FINISH: vinyl, full height	

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	
HYBA-009	BASIN: handwash, Type A, scrub	1	1	
FQCW-005	BIN: waste, clinical, 20L	3	1	

**Room Name | Ultrasound Room - Procedures**
**Room Number ULTR-PR**

AusHFG code	Description	Group	Qty	Comment
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-043	BIN: waste, sharps, on trolley	3	1	
FIHR-004	BRACKET: for display screen, ceiling mounted	1	1	
FIHR-019	BRACKET: for suction bottle	2	1	
FIJO-212	BULKHEAD: joinery	1	1	
FQSN-031	CABINET: short, single door, tambour, adj shelves, lockable	3	1	
FQBS-018	CHAIR: office, ergonomic	3	1	
FQBS-028	CHAIR: visitor, clinical areas	3	1	optional
ITCL-014	CLOCK: analogue, electric	1	1	
ITNE-007	COMPUTER: desktop, with display screen	3	1	
FIJO-157	CUPBOARD: wall mount, single door, adj shelves, lockable	1	1	
FQGE-010	CURTAIN: privacy screen	3	1	to entry door
MMMI-329	DEVICE: imaging, ultrasound scanning unit	3	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MMMI-340	DISPLAY SCREEN: slave, for ultrasound	3	1	
MGFP-004	FLOWMETER: oxygen	3	1	
FIHR-026	HOOK: coat	1	2	optional
MMGE-048	LINEN CARRIER: dirty, single	3	1	
FIHR-055	RACK: scanhead	3	1	
MMGE-169	SLING: arm, dynamic, ceiling mounted	3	1	
FQBS-051	STOOL: mobile, adj height	3	1	
MMGE-100	SUCTION BOTTLE	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	
FIRT-041	TRACK: curtain, privacy, U shaped, angled	1	1	
MMBE-043	TROLLEY: patient, examination	3	1	
MMGE-138	TROLLEY: preparation	3	1	
MMMI-376	WARMER: gel	3	1	
FQDW-028	WORKSTATION: straight, adj height, 1200W x 750D x 750H nom.	3	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light

**Room Name** | **Ultrasound Room - Procedures**
**Room Number** **ULTR-PR**

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	2	
ELGP-223	GPO: emergency power, double, wall mounted	1	2	2 - scanning station, 2 - desk
ELGP-122	GPO: emergency power, single, on services panel	1	2	
ELGP-123	GPO: emergency power, single, wall mounted	1	1	ultrasound machine
ELGP-101	GPO: single, ceiling mounted	1	1	for slave display screen
ELGP-105	GPO: single, on services panel	1	2	
ELGP-109	GPO: single, wall mounted	1	1	to patient bed
ELGP-109	GPO: single, wall mounted	1	1	clock
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	call button on the handset
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	3	2-scanning station; 1-desk
ITIN-061	OUTLET: HDMI, ceiling mounted	1	1	
ITIN-066	OUTLET: HDMI, wall mounted	1	1	
MGAS-032	OUTLET: nitrous oxide (N2O), on services panel	1	1	optional, for invasive procedures
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	
MGAS-053	OUTLET: scavenge, on services panel	1	1	optional, if N2O is required
MGAS-062	OUTLET: suction, on services panel	1	1	
ELPR-006	RCD: residual current device	1	2	
MMSP-026	SERVICES PANEL: wall mounted	1	1	
ELBO-012	SWITCH: light, dimmer	1	1	