

Room Name	Ultrasound		Room Number ULTR
Revision	3		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	14.00 m ²		
Hours of Operation	Available 24 Hours		
Occupancy	1 patient with up to 1 support person; 1-2 staff		
Acoustics	Acoustic privacy is required		
Remarks			
Description / Special Requirements	Room for diagnostic ultrasound procedures, located close to patient toilet and change rooms. The room will require access for patients on hospital beds.		
SERVICES			
General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = Yes LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = Yes		

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	flush set plasterboard ceiling also acceptable
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-021	DOOR: 1400mm c/o, 1 1/2 leaf, solid core, paint	
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	equal to Acrovyn
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	refer to BHWS-B (similar)
MMBE-010	BED: patient, electric with mattress	3	1	
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	at 1000H, open under part
FQCW-016	BIN: waste, general, 20L	3	1	to basin

Room Name | Ultrasound
Room Number ULTR

AusHFG code	Description	Group	Qty	Comment
FIHR-004	BRACKET: for display screen, ceiling mounted	1	1	
FQBS-018	CHAIR: office, ergonomic	3	1	
FQBS-028	CHAIR: visitor, clinical areas	3	2	optional
FQGE-005	CLOCK: analogue, battery operated	3	1	
MMBE-024	COUCH: examination, manual, mobile	3	1	mobile
FIJO-120	CUPBOARD: tall, double door, sliding, adj shelves	3	1	lockable, optional
FIJO-140	CUPBOARD: underbench, single door, adj shelves	1	1	under part bench
FIJO-145	CUPBOARD: wall mount, double door, adj shelves, lockable	1	1	over bench
FIJO-157	CUPBOARD: wall mount, single door, adj shelves, lockable	1	1	over bench
FQGE-010	CURTAIN: privacy screen	3	1	to entry door
MMMI-329	DEVICE: imaging, ultrasound scanning unit	3	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MMMI-340	DISPLAY SCREEN: slave, for ultrasound	3	1	
FQBS-037	FOOTSTOOL	3	1	
FIHR-026	HOOK: coat	1	1	
FIHR-055	RACK: scanhead	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-049	TELEPHONE: handset, desktop	3	1	
FIRT-032	TRACK: curtain, privacy, L shaped	1	1	to entry door
FQSM-016	TROLLEY	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ELGP-208	GPO: double, wall mounted	1	3	2 - staff workstation; 1- bench
ELGP-209	GPO: double, wall mounted, RCD protected	1	1	at bedhead
ELGP-106	GPO: single, special, for equipment	1	1	Ultrasound machine
ELGP-109	GPO: single, wall mounted	1	2	exam couch
ELGP-110	GPO: single, wall mounted, cleaner	1	1	as required
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	call button on the handset
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ELBO-015	SWITCH: light, single	1	1	