

Room Name	Ultrasound Room		Room Number	ULTR
<b>Revision</b>	4			
<b>Issue Date</b>	29.05.2019			
<b>BRIEFING</b>				
<b>Briefed Area</b>	14.00 m <sup>2</sup>			
<b>Hours of Operation</b>	Available 24 Hours			
<b>Occupancy</b>	1 patient with up to 1 support person; 1-2 staff			
<b>Acoustics</b>	Acoustic privacy is required			
<b>Remarks</b>				
<b>Description / Special Requirements</b>	Room for diagnostic ultrasound imaging, located close to patient toilet and change rooms. The room will require access for patients on hospital beds.			
<b>SERVICES</b>				
<b>General Requirements</b>	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED	<input type="checkbox"/>
<b>Air</b>	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered	<input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION	<input type="checkbox"/>
<b>Lighting</b>	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable	<input checked="" type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect	<input type="checkbox"/>
<b>Nurse Call</b>	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>		

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	tiled ceiling also acceptable
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWSC-012	DOOR: 1200mm c/o, 1 1/2 leaf, solid core, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin; selection of material to comply with AHFG Part D Infection Control
WLWA-025	WALL FINISH: vinyl, to 1200 AFFL	

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	

**Room Name | Ultrasound Room**
**Room Number ULTR**

AusHFG code	Description	Group	Qty	Comment
FQCW-005	BIN: waste, clinical, 20L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FIHR-004	BRACKET: for display screen, ceiling mounted	1	1	
FIJO-212	BULKHEAD: joinery	1	1	
FQSN-031	CABINET: short, single door, tambour, adj shelves, lockable	3	1	
FQBS-018	CHAIR: office, ergonomic	3	1	
FQBS-028	CHAIR: visitor, clinical areas	3	1	optional
ITCL-014	CLOCK: analogue, electric	1	1	
ITNE-007	COMPUTER: desktop, with display screen	3	1	
FIJO-157	CUPBOARD: wall mount, single door, adj shelves, lockable	1	1	over mobile storage unit
FQGE-010	CURTAIN: privacy screen	3	2	1-internal to entry door, 1-external to entry door optional
MMMI-329	DEVICE: imaging, ultrasound scanning unit	3	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MMMI-340	DISPLAY SCREEN: slave, for ultrasound	3	1	
FIHR-026	HOOK: coat	1	2	optional
MMGE-048	LINEN CARRIER: dirty, single	3	1	
FIHR-055	RACK: scanhead	3	1	
MMGE-169	SLING: arm, dynamic, ceiling mounted	3	1	
FQBS-051	STOOL: mobile, adj height	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	
FIRT-031	TRACK: curtain, privacy	1	1	optional, external to entry doors
FIRT-032	TRACK: curtain, privacy, L shaped	1	1	
FQSM-016	TROLLEY	3	1	for gel warmer
MMBE-043	TROLLEY: patient, examination	3	1	
MMMI-376	WARMER: gel	3	1	on trolley
FQDW-028	WORKSTATION: straight, adj height, 1200W x 750D x 750H nom.	3	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ELGP-208	GPO: double, wall mounted	1	2	desk

**Room Name | Ultrasound Room**
**Room Number ULTR**

AusHFG code	Description	Group	Qty	Comment
ELGP-223	GPO: emergency power, double, wall mounted	1	2	scanning station
ELGP-122	GPO: emergency power, single, on services panel	1	2	patient services panel
ELGP-123	GPO: emergency power, single, wall mounted	1	1	
ELGP-101	GPO: single, ceiling mounted	1	1	for slave display screen
ELGP-105	GPO: single, on services panel	1	2	
ELGP-109	GPO: single, wall mounted	1	1	clock
ELGP-109	GPO: single, wall mounted	1	1	to patient bed
ELGP-110	GPO: single, wall mounted, cleaner	1	1	as required
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	call button on the handset
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	3	2-scanning station; 1-desk
ITIN-061	OUTLET: HDMI, ceiling mounted	1	1	
ITIN-066	OUTLET: HDMI, wall mounted	1	1	
ELPR-006	RCD: residual current device	1	2	
MMSP-026	SERVICES PANEL: wall mounted	1	1	
ELBO-012	SWITCH: light, dimmer	1	1	