

Room Name	Waiting, 10m2		Room Number	WAIT-10
<b>Revision</b>	6			
<b>Issue Date</b>	24.06.2022			
<b>BRIEFING</b>				
<b>Briefed Area</b>	10.00 m <sup>2</sup>			
<b>Hours of Operation</b>	24 Hours			
<b>Occupancy</b>	Up to 8			
<b>Acoustics</b>	Sound attenuation level - high			
<b>Remarks</b>				
<b>Description / Special Requirements</b>	<p>An area for visitors, families and patients to wait prior to or during visits to a department. A range of occupants will need to be accommodated including adults, children, able-bodied persons and people with disabilities. In many instances bariatric capacity will also be required. The size of waiting areas can vary depending on service requirements; add 1.2m<sup>2</sup> per additional person and allow 1.5m<sup>2</sup> for additional wheelchair spaces as required. Waiting areas may be shared between departments. Public amenities including baby change facilities should be located nearby. An external outlook is desirable.</p> <p>Additional Considerations:</p> <ul style="list-style-type: none"> <li>Consider furniture options including weight rating of all chairs and providing built-in furniture or securing furniture where there may be safety/security concerns.</li> <li>Wall protection is recommended to protect wall linings and finishes from damage due to movement of loose furniture.</li> <li>Acoustic treatments may be considered as required to ensure the noise level in the space is comfortable both in the waiting area and adjacent reception areas.</li> <li>Check-in kiosks may be located nearby and services will need to be confirmed based on system requirements.</li> <li>Provision of a hearing augmentation system may be required where a built in amplification system is provided, if a TV monitor is installed.</li> <li>Hand hygiene facilities, such as alcohol-based hand rub, should be provided in line with local infection control policies.</li> </ul>			
<b>SERVICES</b>				
<b>Electrical</b>	BODY PROTECTED	<input type="checkbox"/>	CARDIAC PROTECTED	<input type="checkbox"/>
<b>HVAC</b>	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered	<input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION	<input type="checkbox"/>
<b>Lighting</b>	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable	<input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect	<input type="checkbox"/>
<b>Security / Nurse Call</b>	NURSE CALL SYSTEM	<input type="checkbox"/>		

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-009	CORNICE: wall trim fixing	
FLVY-003	FLOOR FINISH: vinyl, seamless, coved, non slip	carpet tiles are also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	

**Room Name** | **Waiting, 10m2**
**Room Number WAIT-10**

AusHFG code	Description	Comment
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-022	WALL FINISH: vinyl, to 900 AFFL	as required to suit loose furniture layout; crash rails are also acceptable
WLPR-006	WALL PROTECTION: corner guards	coordinated with adjacent wall protection
DWWH-005	WINDOW	desirable

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
FQGE-002	ARTWORK	3	1	optional
FQCW-016	BIN: waste, general, 20L	3	1	
DWWD-004	BLIND: roller	3	1	desirable, associated with window
FIHR-006	BRACKET: for display screen, wall mounted	2	1	
FQBS-027	CHAIR: visitor, bariatric	3	1	quantity dependent on service requirements
FQBS-032	CHAIR: waiting	3	6	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	to suit local infection control policies
ITBU-011	DISPLAY SCREEN: MATV	3	1	
FIHR-045	RACK: magazine/pamphlet	2	1	optional
FQTA-071	TABLE: square, 500W, low height	3	1	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	optional

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	1	
ELGP-109	GPO: single, wall mounted	1	1	to television
ITIN-070	OUTLET: MATV	1	1	may be replaced with data outlet in accordance with ICT policy