

| Room Name | Waiting, 20m2 | | Room Number | WAIT-20 |
|---|---|-------------------------------------|---|--------------------------|
| Revision | 6 | | | |
| Issue Date | 24.06.2022 | | | |
| BRIEFING | | | | |
| Briefed Area | 20.00 m ² | | | |
| Hours of Operation | 24 Hours | | | |
| Occupancy | Up to 17 | | | |
| Acoustics | Sound attenuation level - high | | | |
| Remarks | | | | |
| Description / Special Requirements | <p>An area for visitors, families and patients to wait prior to or during visits to a department. A range of occupants will need to be accommodated including adults, children, able-bodied persons and people with disabilities. In many instances bariatric capacity will also be required. The size of waiting areas can vary depending on service requirements; add 1.2m² per additional person and allow 1.5m² for additional wheelchair spaces as required. Waiting areas may be shared between departments. Public amenities including baby change facilities should be located nearby. An external outlook is desirable.</p> <p>Additional Considerations:</p> <ul style="list-style-type: none"> Consider furniture options including weight rating of all chairs and providing built-in furniture or securing furniture where there may be safety/security concerns. Wall protection is recommended to protect wall linings and finishes from damage due to movement of loose furniture. Acoustic treatments may be considered as required to ensure the noise level in the space is comfortable both in the waiting area and adjacent reception areas. Check-in kiosks may be located nearby and services will need to be confirmed based on system requirements. Provision of a hearing augmentation system may be required where a built in amplification system is provided, if a TV monitor is installed. Hand hygiene facilities, such as alcohol-based hand rub, should be provided in line with local infection control policies. | | | |
| SERVICES | | | | |
| Electrical | BODY PROTECTED | <input type="checkbox"/> | CARDIAC PROTECTED | <input type="checkbox"/> |
| HVAC | AIRCONDITIONING | <input checked="" type="checkbox"/> | AIRCONDITIONING: hepa filtered | <input type="checkbox"/> |
| | AIRCONDITIONING: positive pressure | <input type="checkbox"/> | AIRCONDITIONING: negative pressure | <input type="checkbox"/> |
| | EXHAUST: room exhaust | <input type="checkbox"/> | VENTILATION | <input type="checkbox"/> |
| Lighting | LIGHTING: colour corrected | <input type="checkbox"/> | LIGHTING: dimmable | <input type="checkbox"/> |
| | LIGHTING: downlights | <input type="checkbox"/> | LIGHTING: downlights, dimmable | <input type="checkbox"/> |
| | LIGHTING: fluorescent/LED, downlights | <input type="checkbox"/> | LIGHTING: fluorescent/LED, flush with ceiling, tamper proof | <input type="checkbox"/> |
| | LIGHTING: fluorescent/LED, general | <input checked="" type="checkbox"/> | LIGHTING: indirect | <input type="checkbox"/> |
| Security / Nurse Call | NURSE CALL SYSTEM | <input type="checkbox"/> | | |

Room Fabrics

| AusHFG code | Description | Comment |
|-------------|---|----------------------------------|
| CLTI-002 | CEILING: acoustic, drop-in tiles, 600 x 1200 | |
| CLCN-009 | CORNICE: wall trim fixing | |
| FLVY-003 | FLOOR FINISH: vinyl, seamless, coved, non slip | carpet tiles are also acceptable |
| FLSK-010 | SKIRTING: vinyl, floor vinyl coved, 150H, prefinished | |
| WLWA-004 | WALL FINISH: paint, acrylic, washable | |

Room Name | **Waiting, 20m2**
Room Number WAIT-20

| AusHFG code | Description | Comment |
|-------------|---------------------------------|---|
| WLWA-022 | WALL FINISH: vinyl, to 900 AFFL | as required to suit loose furniture layout; crash rails are also acceptable |
| WLPR-006 | WALL PROTECTION: corner guards | coordinated with adjacent wall protection |
| DWWH-005 | WINDOW | desirable |

Fittings, Furniture and Equipment (FF&E) Items

| AusHFG code | Description | Group | Qty | Comment |
|-------------|---|-------|-----|--|
| FQGE-002 | ARTWORK | 3 | 1 | optional |
| FQCW-016 | BIN: waste, general, 20L | 3 | 1 | |
| DWWD-004 | BLIND: roller | 3 | 1 | desirable, associated with window |
| FIHR-006 | BRACKET: for display screen, wall mounted | 2 | 1 | |
| FQBS-027 | CHAIR: visitor, bariatric | 3 | 2 | quantity dependent on service requirements |
| FQBS-032 | CHAIR: waiting | 3 | 14 | |
| FIDI-001 | DISPENSER: alcohol based hand rub | 2 | 1 | to suit local infection control policies |
| ITBU-011 | DISPLAY SCREEN: MATV | 3 | 1 | |
| FIHR-045 | RACK: magazine/pamphlet | 2 | 1 | optional |
| FQTA-071 | TABLE: square, 500W, low height | 3 | 2 | |
| FIBM-019 | WHITEBOARD: fixed, magnetic | 2 | 1 | optional |

Engineering Services

| AusHFG code | Description | Group | Qty | Comment |
|-------------|---------------------------|-------|-----|--|
| ELGP-208 | GPO: double, wall mounted | 1 | 2 | |
| ELGP-109 | GPO: single, wall mounted | 1 | 1 | to television |
| ITIN-070 | OUTLET: MATV | 1 | 1 | may be replaced with data outlet in accordance with ICT policy |