

Room Name	Toilet - Accessible, 6m2		Room Number WCAC
<b>Revision</b>	5		
<b>Issue Date</b>	20.03.17		
<b>BRIEFING</b>			
<b>Briefed Area</b>	5.00 m <sup>2</sup>		
<b>Hours of Operation</b>	24 Hours		
<b>Occupancy</b>	1		
<b>Acoustics</b>	Sound attenuation level high, Acoustic privacy is required.		
<b>Remarks</b>			
<b>Description / Special Requirements</b>	A toilet and handbasin for use by disabled persons with or without assistance. The room shall comply with AS 1428. Baby change facilities may also be located in this room. The room may be used by patients or visitors. If the Accessible Toilet is located in a patient care area the patient/nurse call and emergency call points should be included. Additional design requirements: The entrance is to be flush with the adjoining floor. The door is to be fitted with escape hardware.		
<b>SERVICES</b>			
<b>General Requirements</b>	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
<b>Air</b>	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = Yes	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
<b>Lighting</b>	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
<b>Nurse Call</b>	NURSE CALL SYSTEM = Yes		

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-014	CEILING: plasterboard, water resistant, drop-in tiles, prefinished, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	privacy latch, emergency release
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	Both sides, equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Optional. To be decided at project level.
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	Default = Vinyl; tiles also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	Default = Vinyl coved; or tiles for tiled floor
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	Selection of material to comply with Part D Infection Prevention and Control AusHFG.

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
HYBA-005	BASIN: handwash, accessible	1	1	

**Room Name** | Toilet - Accessible, 6m2

**Room Number WCAC**

AusHFG code	Description	Group	Qty	Comment
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-037	BIN: waste, sanitary	3	1	Optional, depends on Waste Management Policy.
FQBS-035	CHANGE TABLE: baby	1	1	optional
FIDI-025	DISPENSER: paper/hand towel	2	1	
FIDI-030	DISPENSER: soap	2	1	to handbasin
FIDI-036	DISPENSER: toilet paper	1	1	
FIRT-006	GRAB RAIL: WC	1	1	
FIRT-007	GRAB RAIL: WC, accessible use	1	1	behind toilet
FIHR-026	HOOK: coat	1	2	
FIBM-006	MIRROR: fixed, glass	1	1	
HYTP-035	TAPWARE: mixer, basin, accessible	1	1	fixture mounted
HYWC-001	TOILET SUITE: accessible	1	1	With backrest. Concealed cistern, optional.

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light, optional
ITCL-006	BUTTON: nurse call, patient to staff	1	1	+ indicator button & light, optional
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light, optional
HYDR-004	DRAIN: floor waste	1	1	
ELBO-015	SWITCH: light, single	1	1	