

Room Name	Toilet - Patient, 4m2		Room Number WCPT
Revision	3		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	4.00 m ²		
Hours of Operation	24 Hours		
Occupancy	1 patient; 1 staff assisting as required		
Acoustics	Sound attenuation level high, Acoustic privacy is required.		
Remarks			
Description / Special Requirements	The Patient Toilet is a room containing a toilet and a handbasin for patients to use independently or with nurse assistance. Maybe provided for multi-bed rooms, Ambulatory Care Units, Emergency Departments, etc. The door will be fitted with escape hardware to allow staff access in an emergency.		
SERVICES			
General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = No AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = Yes	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = Yes	
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = Yes LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = Yes		

Room Fabrics

AusHFG code	Description	Comment
CLTI-014	CEILING: plasterboard, water resistant, drop-in tiles, prefinished, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	privacy latch, emergency release
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	Default = Vinyl; tiles also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	Or tiles for tiled floor.
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-002	BASIN: ensuite, with vanity unit	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-037	BIN: waste, sanitary	3	1	Optional, depends on Waste Management Policy.

Room Name | Toilet - Patient, 4m2

Room Number WCPT

AusHFG code	Description	Group	Qty	Comment
FIDI-025	DISPENSER: paper/hand towel	2	1	
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-036	DISPENSER: toilet paper	1	1	
FIRT-005	GRAB RAIL: stainless steel	1	1	1 behind toilet
FIRT-006	GRAB RAIL: WC	1	1	1 to side or wrap-around.
FIRT-008	GRAB RAIL: WC, hinged	1	1	optional, drop down rail
FIHR-026	HOOK: coat	1	2	
FIBM-006	MIRROR: fixed, glass	1	1	
HYTP-036	TAPWARE: mixer, basin, lever action	1	1	
HYWC-006	TOILET SUITE: patient	1	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
HYDR-004	DRAIN: floor waste	1	1	
ELGP-208	GPO: double, wall mounted	1	1	