

# Australasian Standard Project

## Room Data Sheets

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag: 4640</b>
<b>Room Name</b>	<b>Treatment Bay - Renal Dialysis</b>	<b>Room Code: TRMT-RD</b>
<b>Area</b>	9.0 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Area</b>	9.0 M2	
<b>Hours of Operation</b>	0800 Hours to 1800 Hours, daily	
<b>Occupancy</b>	1 patient, 1 support person, 1 staff assisting	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	<p>The Treatment Bay - Renal Dialysis is used for day treatment of patients undergoing renal dialysis treatments. Treatments for each patient may take from 3 to 6 hours, for 3 days per week. Natural light is desirable. Furniture and furnishings should provide a high level of patient comfort and amenity. A staff handwashing basin will be located in close proximity.</p> <p>Body Protected electrical area</p>	
<b>Amendment</b>	<p>11.03.05, - First Draft 21.03.05, - BOB User review; Group 3 fittings modified</p>	

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		Minimum height 2700mm, flush set plasterboard ceiling also acceptable
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3092	Wall protection	MDF	Laminate	Bed protection wall panel		
7001	Windows					Desirable

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
150	Air flowmeter	Furniture/ Fitting	3	1	optional
1250	Blind: Venetian	Metalwork	3	1	to external windows, if provided
1465	Bracket: suction bottle	Furniture/ Fitting	2	1	
23400	Bracket: television, ceiling	Metalwork	1	1	
2200	Chair: recliner	Furniture/ Fitting	3	1	or patient bed
2650	Chair: visitor, patient	Furniture/ Fitting	3	1	
4600	Curtain track: bed screen	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
16250	Oxygen flowmeter	Furniture/ Fitting	3	1	
21950	Suction adapter	Furniture/ Fitting	3	1	
22000	Suction bottle	Furniture/ Fitting	3	1	
16200	Table: overbed	Furniture/ Fitting	3	1	may use a fixed table attached to a recliner chair

# Australasian Standard Project

## Room Data Sheets

Department **Standard Components**  
 Room Name **Treatment Bay - Renal Dialysis**

Room Tag: **4640**  
 Room Code: **TRMT-RD**

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
15980	Dialysis machine	3	1	yes	___	yes	___	___	___	yes	___	
15985	Dialysis station	1	1	___	___	yes	___	yes	yes	yes	___	RO reticulated water and drain
31700	Light: examination, ceiling	1	1	yes	___	___	___	___	___	___	___	
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	
54550	Television: 34 cm	3	1	yes	___	___	___	___	___	___	___	

### Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	1	
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
6050	Special: reading	Lighting		
7020	Medical Air (MA)	Medical Gases	1	optional
7000	Oxygen (O2)	Medical Gases	1	
7040	Suction	Medical Gases	1	
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9001	GPO: Double	Power	2	
9010	GPO: Emergency power, single	Power	2	
9060	GPO: Special: for equipment	Power	2	TV, exam light